



**REGISTER
OF
PORTABLE APPLIANCE TESTS**

On Behalf Of:

D &W Disco
Flat 13 Wight House
Explorer Drive
Tolpits Lane
Watford
WD18 6GT

Site Tested

D &W Disco
Flat 13 Wight House
Explorer Drive
Tolpits Lane
Watford
WD18 6GT

Date of Tests 15 May 2016



Test Certificate



Tests Conducted By: JPS Calibration Services Ltd, Commerce House, Telford Road, Bicester, Oxfordshire, OX26 4LD

On Behalf Of: D&W Discos , Flat 13 Wight House, Explorer Drive, Tolpits Lane, Watford, Herts, WD18 6GT

Site: D&W Discos . Flat 13 Wight House. Explorer Drive. Tolpits Lane. Watford. Herts. WD18 6GT

Location: D&W Discos . Flat 13 Wight House. Explorer Drive. Tolpits Lane. Watford. Herts. WD18 6GT

Number of Tests: 77 Number PASSED: 77 Number FAILED: 0

Number of Pages in Report: 11

Comments:

0 Fuses downrated to appropriate rating for flex csa.

The tests performed only indicate the status of the safety of the Unit Under Test and, although a functional test is performed, should not be misinterpreted as a verification of the units compliance with operational specifications. It must also be understood that some appliances (Class1) rely upon the fixed wiring of the socket to ensure continuity of the Earth connection. These Portable Appliance tests ensure the appliance under test has the correct Earth connection resistance but cannot ensure the continuity within the Fixed wiring of the supply and that Further Fixed wiring periodic tests are required.

Date of Tests: 15 May 2016

Test Instrument: JPS0253A

Calibration Certificate Number: 16-050201

Calibration Due Date: 05 Feb 2017

Tested By: John Preston

Signed By:

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Client: D&W Discos		Site: Flat 13 Watford		Location:
Asset ID: A01633	Description: IEC LEAD 5A			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.05	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Polarity	15/05/2016			Pass
Overall: Pass				
Asset ID: A01634	Description: IEC LEAD 5A			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.05	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Polarity	15/05/2016			Pass
Overall: Pass				
Asset ID: A01636	Description: IEC LEAD 5A			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.05	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Polarity	15/05/2016			Pass
Overall: Pass				
Asset ID: A01637	Description: IEC LEAD 5A			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.06	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Polarity	15/05/2016			Pass
Overall: Pass				
Asset ID: A01641	Description: EXT LEAD			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.12	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Polarity	15/05/2016			Pass
Overall: Pass				
Asset ID: A01647	Description: EXT LEAD			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.09	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Polarity	15/05/2016			Pass
Overall: Pass				
Asset ID: A01650	Description: 1.5M IEC ADAPTOR FLEX			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.11	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Polarity	15/05/2016			Pass
Overall: Pass				
Asset ID: A01651	Description: IEC ADAPTOR FLEX 3M			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.15	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Polarity	15/05/2016			Pass
Overall: Pass				
Asset ID: A01652	Description: 4M IEC ADAPTOR FLEX			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.22	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Polarity	15/05/2016			Pass
Overall: Pass				
Asset ID: A01654				
Description: IEC LEAD 5A				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.06	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Polarity	15/05/2016			Pass
Overall: Pass				
Asset ID: A01655				
Description: EXT REEL 12M				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.24	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Polarity	15/05/2016			Pass
Overall: Pass				
Asset ID: A01656				
Description: EXT REEL 25M				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.49	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Polarity	15/05/2016			Pass
Overall: Pass				
Asset ID: A01657				
Description: SOUNDLAB MUSHROOM LIGHT Model:SRL448 Serial:03060				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Insulation	15/05/2016	>99.99	MOhm	Pass
Earth	15/05/2016	0.1	Ohms	Pass
Overall: Pass				
Asset ID: A01658				
Description: SKYTEC MUSHROOM LIGHT Model:TL-007 Serial:1680103				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Insulation	15/05/2016	>99.99	MOhm	Pass
Earth	15/05/2016	0.12	Ohms	Pass
Overall: Pass				
Asset ID: A01659				
Description: FLOWER EFFECT LIGHT Model:150-283UK Serial:213000				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.06	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01662				
Description: CLASS2 LEAD				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01663				
Description: LAPTOP XFORMER				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01664				
Description: RADIOMIC				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01665				
Description: 4 WAY CHASER LIGHT Model L70AK Serial:1680306073-				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	15/05/2016			Pass
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.04	Ohm	Pass
Earth	15/05/2016	0.04	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	Overall: Pass
Asset ID: A01667 Description: SOUNDLABS AMPLIFIER Model:SP6 Serial:K0006221					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	4	A	Information	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Earth	15/05/2016	0.15	Ohms	Pass	
					Overall: Pass
Asset ID: A01669 Description: NJD DISCO LIGHT Model: DATAMOON Serial:452101213					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.07	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01670 Description: NJD DISCO LIGHT Model:DATAMOON Serial:452101271					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Earth	15/05/2016	0.11	Ohms	Pass	
					Overall: Pass
Asset ID: A01671 Description: ACME EXERCET Model:MH-270M Serial:AE-02030678					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Earth	15/05/2016	0.14	Ohms	Pass	
					Overall: Pass
Asset ID: A01672 Description: ACME EXERCET Model:MH-270M Serial:08020122					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.06	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01684 Description: IEC LEAD 5A					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.04	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
					Overall: Pass
Asset ID: A01685 Description: ACME DMX LIGHT Model:MH275R Serial:PL09050936					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.05	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01686 Description: IEC LEAD 5A					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.06	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
					Overall: Pass
Asset ID: A01687 Description: ACME DMX LIGHT Model:MH-275R Serial:PL09050915					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.06	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01688 Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Earth Current	15/05/2016	25	A	Information
Insulation	15/05/2016	>99.99	MOhm	Pass
Earth	15/05/2016	0.12	Ohms	Pass
Overall: Pass				

Asset ID: A01689	Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Earth	15/05/2016	0.11	Ohms	Pass	
Overall: Pass					

Asset ID: A01690	Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:090				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.08	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Overall: Pass					

Asset ID: A01691	Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Earth	15/05/2016	0.1	Ohms	Pass	
Overall: Pass					

Asset ID: A01692	Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.08	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Overall: Pass					

Asset ID: A01693	Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.06	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Overall: Pass					

Asset ID: A01702	Description: MERRY CHRISTMAS LIGHT				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Leakage	15/05/2016	<0.1	mA	Pass	
Load	15/05/2016	0.08	kVA	Information	
Overall: Pass					

Asset ID: A109084	Description: IEC ADAPTOR				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.1	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
Overall: Pass					

Asset ID: A109085	Description: IEC LEAD 5A				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.05	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
Overall: Pass					

Asset ID: A109086	Description: IEC LEAD 5A				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.06	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	Overall: Pass
Asset ID: A109087					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Earth	15/05/2016	0.12	Ohms	Pass	
					Overall: Pass
Asset ID: A109088					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Earth	15/05/2016	0.14	Ohms	Pass	
					Overall: Pass
Asset ID: A109089					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.04	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
					Overall: Pass
Asset ID: A109090					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.04	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
					Overall: Pass
Asset ID: A109091					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	<0.04	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
					Overall: Pass
Asset ID: A140131					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	10	A	Information	
Earth	15/05/2016	0.07	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A140132					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	4	A	Information	
Earth	15/05/2016	0.08	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A140133					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.04	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
					Overall: Pass
Asset ID: A140134					Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.08	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
					Overall: Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A140135					Description: LIGHTBAR
Test Type					Date
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.07	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Overall: Pass					Test Instrument: 45B-0625
Asset ID: A140136					Description: IEC LEAD 10A
Test Type					Date
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.05	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
Overall: Pass					Test Instrument: 45B-0625
Asset ID: A140137					Description: IEC LEAD 10A
Test Type					Date
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.05	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
Overall: Pass					Test Instrument: 45B-0625
Asset ID: A140138					Description: EXTENSION REEL
Test Type					Date
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.29	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
Overall: Pass					Test Instrument: 45B-0625
Asset ID: A142246					Description: SOUNDLAB LIGHT
Test Type					Date
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.05	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Overall: Pass					Test Instrument: 45B-0625
Asset ID: A142247					Description: SOUNDLAB LIGHT
Test Type					Date
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.04	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Overall: Pass					Test Instrument: 45B-0625
Asset ID: A142248					Description: LAMP
Test Type					Date
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.08	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Overall: Pass					Test Instrument: 45B-0625
Asset ID: A142249					Description: LAMP
Test Type					Date
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.11	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Overall: Pass					Test Instrument: 45B-0625
Asset ID: A142250					Description: IEC LEAD 10A
Test Type					Date
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.15	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
Overall: Pass					Test Instrument: 45B-0625
Asset ID: A142251					Description: LAMP
Test Type					Date
Visual	15/05/2016			Pass	

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Earth Current	15/05/2016	25	A	Information
Earth	15/05/2016	0.06	Ohm	Pass
Insulation	15/05/2016	>99.99	MOhm	Pass
Overall: Pass				

Asset ID: A142252	Description: IEC ADAPTOR				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.1	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
Overall: Pass					

Asset ID: A142253	Description: LIGHT CONTROLLER				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	10	A	Information	
Earth	15/05/2016	0.06	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Overall: Pass					

Asset ID: A142254	Description: TRANSFORMER				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Overall: Pass					

Asset ID: A142255	Description: IEC ADAPTOR				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.09	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
Overall: Pass					

Asset ID: A21371	Description: EXT LEAD				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.12	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
Overall: Pass					

Asset ID: A21372	Description: EXT LEAD				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.09	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
Overall: Pass					

Asset ID: A21373	Description: HOMEBASE DESKLAMP Model GYT107 Serial:28112005				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Overall: Pass					

Asset ID: A59475	Description: PEAVEY AMP				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	4	A	Information	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Earth	15/05/2016	0.16	Ohms	Pass	
Overall: Pass					

Asset ID: A59476	Description: IEC LEAD 5A				Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	15/05/2016			Pass	
Earth Current	15/05/2016	25	A	Information	
Earth	15/05/2016	0.05	Ohm	Pass	
Insulation	15/05/2016	>99.99	MOhm	Pass	
Polarity	15/05/2016			Pass	
Overall: Pass					

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A59477					Description: URSA LASER
Test Type					Date
Visual	15/05/2016				Pass
Earth Current	15/05/2016	25	A		Information
Earth	15/05/2016	0.05	Ohm		Pass
Insulation	15/05/2016	>99.99	MOhm		Pass
Insulation	15/05/2016	>99.99	MOhm		Pass
					Overall: Pass
Asset ID: A59478					Description: IEC LEAD 5A
Test Type					Date
Visual	15/05/2016				Pass
Earth Current	15/05/2016	25	A		Information
Earth	15/05/2016	0.06	Ohm		Pass
Insulation	15/05/2016	>99.99	MOhm		Pass
Polarity	15/05/2016				Pass
					Overall: Pass
Asset ID: A59479					Description: MIXER NUMARK
Test Type					Date
Visual	15/05/2016				Pass
Insulation	15/05/2016	>99.99	MOhm		Pass
					Overall: Pass
Asset ID: A59480					Description: CD PLAYER
Test Type					Date
Visual	15/05/2016				Pass
Insulation	15/05/2016	>99.99	MOhm		Pass
					Overall: Pass
Asset ID: A59481					Description: SMOKE MC
Test Type					Date
Visual	15/05/2016				Pass
Earth Current	15/05/2016	25	A		Information
Earth	15/05/2016	0.07	Ohm		Pass
Insulation	15/05/2016	>99.99	MOhm		Pass
					Overall: Pass
Asset ID: A59482					Description: IEC LEAD 5A
Test Type					Date
Visual	15/05/2016				Pass
Earth Current	15/05/2016	25	A		Information
Earth	15/05/2016	0.06	Ohm		Pass
Insulation	15/05/2016	>99.99	MOhm		Pass
Polarity	15/05/2016				Pass
					Overall: Pass
Asset ID: A69503					Description: EXT LEAD
Test Type					Date
Visual	15/05/2016				Pass
Earth Current	15/05/2016	25	A		Information
Earth	15/05/2016	0.11	Ohm		Pass
Insulation	15/05/2016	>99.99	MOhm		Pass
Polarity	15/05/2016				Pass
					Overall: Pass
Asset ID: A69504					Description: CLASS2 LEAD
Test Type					Date
Visual	15/05/2016				Pass
Insulation	15/05/2016	>99.99	MOhm		Pass
					Overall: Pass
Asset ID: A69505					Description: AC ADAPTOR
Test Type					Date
Visual	15/05/2016				Pass
Insulation	15/05/2016	>99.99	MOhm		Pass
					Overall: Pass
Asset ID: A81302					Description: CLASS1 LEAD
Test Type					Date
Visual	15/05/2016				Pass
Earth Current	15/05/2016	25	A		Information
Earth	15/05/2016	0.07	Ohm		Pass
Insulation	15/05/2016	>99.99	MOhm		Pass
					Overall: Pass
Asset ID: A81303					Description: AC ADAPTOR
Test Type					Date
Visual	15/05/2016				Pass

Detailed Latest Test Results



JPS Calibration Services Ltd

Page 9

Automation In Measurement

Test Status: All, Test Type: All

Test_Type	Test_Date	Result	Unit	Status
Insulation	15/05/2016	>99.99	MOhm	Pass

Total Tests: 77

Overall: Pass