



**REGISTER  
OF  
PORTABLE APPLIANCE TESTS**

**On Behalf Of:**

D &W Disco  
115 Leys Road  
Hemel Hempstead  
Herts  
HP3 9JX

**Site Tested**

D &W Disco  
115 Leys Road  
Hemel Hempstead  
Herts  
HP3 9JX

**Date of Tests** 13 March 2011



ISO 9001

Certificate No. FS 78965



# Test Certificate



**Tests Conducted By:** JPS Calibration Services Ltd, Commerce House, Telford Road, Bicester, Oxfordshire, OX26 4LD

**On Behalf Of:** D&W Discos , 115 Leys Road, Hemel Hempstead, HP3 9JX

**Site:**

**Location:**

**Number of Tests:**  **Number PASSED:**  **Number FAILED:**

**Number of Pages in Report:**

**Comments:**

0 Fuses downrated to appropriate rating for flex csa.

IEC Lead A59474 exhibits LOW Insulation Resistance and it is recommended that this item is discarded and replaced.

The tests performed only indicate the status of the safety of the Unit Under Test and, although a functional test is performed, should not be misinterpreted as a verification of the units compliance with operational specifications. It must also be understood that some appliances (Class1) rely upon the fixed wiring of the socket to ensure continuity of the Earth connection. These Portable Appliance tests ensure the appliance under test has the correct Earth connection resistance but cannot ensure the continuity within the Fixed wiring of the supply and that Further Fixed wiring periodic tests are required.

**Date of Tests:**

**Test Instrument:**

**Calibration Certificate Number:**

**Calibration Due Date:**

**Tested By:**

**Signed By:**

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
<b>Client: D&amp;W Discos</b>		<b>Site: 115 Leys Road</b>		<b>Location:</b>
Asset ID: A01632	Description: IEC LEAD 5A			Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.05	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
Asset ID: A01633	Description: IEC LEAD 5A			Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.05	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
Asset ID: A01634	Description: IEC LEAD 5A			Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.05	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
Asset ID: A01635	Description: IEC LEAD 5A			Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.05	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
Asset ID: A01636	Description: IEC LEAD 5A			Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.05	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
Asset ID: A01637	Description: IEC LEAD 5A			Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.04	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
Asset ID: A01638	Description: IEC LEAD 10A			Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.05	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
Asset ID: A01639	Description: IEC LEAD 5A			Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.05	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
Asset ID: A01641	Description: EXT LEAD			Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.13	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Polarity	13/03/2011			Pass
Overall: Pass				
<b>Asset ID: A01642</b>				
<b>Description: EXT LEAD</b>				
<b>Test Instrument: 45B-0625</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.09	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
<b>Asset ID: A01647</b>				
<b>Description: EXT LEAD</b>				
<b>Test Instrument: 45B-0625</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.08	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
<b>Asset ID: A01653</b>				
<b>Description: CD XFORMER</b>				
<b>Test Instrument: 45B-0625</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01654</b>				
<b>Description: IEC LEAD 5A</b>				
<b>Test Instrument: 45B-0625</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.05	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
<b>Asset ID: A01655</b>				
<b>Description: EXT REEL 12M</b>				
<b>Test Instrument: 45B-0625</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.25	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
<b>Asset ID: A01656</b>				
<b>Description: EXT REEL 25M</b>				
<b>Test Instrument: 45B-0625</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.45	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
<b>Asset ID: A01657</b>				
<b>Description: SOUNDLAB MUSHROOM LIGHT Model:SRL448 Serial:03060</b>				
<b>Test Instrument: 45B-0625</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.07	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01658</b>				
<b>Description: SKYTEC MUSHROOM LIGHT Model:TL-007 Serial:1680103</b>				
<b>Test Instrument: 45B-0625</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.07	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01659</b>				
<b>Description: FLOWER EFFECT LIGHT Model:150-283UK Serial:213000</b>				
<b>Test Instrument: 45B-0625</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.07	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
<b>Asset ID: A01661</b>					<b>Description: SOUNDLABS HAZE Machine Model HG002GE</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.09	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01664</b>					<b>Description: RADIOMIC</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01665</b>					<b>Description: 4 WAY CHASER LIGHT Model L70AK Serial:1680306073-</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.04	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01666</b>					<b>Description: INTERM POWER AMP Model:M700 Serial:011016283</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.08	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01667</b>					<b>Description: SOUNDLABS AMPLIFIER Model:SP6 Serial:K0006221</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.07	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01669</b>					<b>Description: NJD DISCO LIGHT Model: DATAMOON Serial:452101213</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.07	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01670</b>					<b>Description: NJD DISCO LIGHT Model:DATAMOON Serial:452101211</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.11	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01671</b>					<b>Description: ACME EXERCET Model:MH-270M Serial:AE-02030678</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.09	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01672</b>					<b>Description: ACME EXERCET Model:MH-270M Serial:08020122</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.07	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01673</b>					<b>Description: SOUNDLABS WHITE LIGHT Model:DK008 Serial: 04040001</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.04	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Overall: Pass				
<b>Asset ID: A01679</b> Description: ACME AUTOMATED LUMINAIRE THE WINNER Serial:PL1204 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.13	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01680</b> Description: ACME AUTOMATED LUMINAIRE THE WINNER Serial:PL1204 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.11	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01681</b> Description: IEC LEAD 5A Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	<0.04	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
<b>Asset ID: A01684</b> Description: IEC LEAD 5A Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.04	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
<b>Asset ID: A01685</b> Description: ACME DMX LIGHT Model:MH275R Serial:PL09050936 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.07	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01686</b> Description: IEC LEAD 5A Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.04	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
<b>Asset ID: A01687</b> Description: ACME DMX LIGHT Model:MH-275R Serial:PL09050915 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.07	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01688</b> Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.11	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01689</b> Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.1	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
<b>Asset ID: A01690</b> Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:090 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.06	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01691</b> Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.07	Ohm	Pass
Earth	13/03/2011	0.07	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01692</b> Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.05	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01693</b> Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.05	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01694</b> Description: IEC LEAD 5A Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.06	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass
Overall: Pass				
<b>Asset ID: A01695</b> Description: KAM MIXER Model:GMX5 MK2 Serial:9924591 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.06	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01696</b> Description: CITRONIC CD UNIT Model:CD2 Serial:K171 B110A 0036 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Insulation	13/03/2011	>99.99	MOhm	Pass
Earth	13/03/2011	0.19	Ohms	Pass
Overall: Pass				
<b>Asset ID: A01697</b> Description: CLASS2 LEAD Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01698</b> Description: NEWMARK CD UNIT Model:CDN22 Serial:H0311216610437 Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01699</b> Description: IEC LEAD 5A Test Instrument: 45B-0625				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	13/03/2011			Pass
Earth Current	13/03/2011	25	A	Information
Earth	13/03/2011	0.05	Ohm	Pass
Insulation	13/03/2011	>99.99	MOhm	Pass
Polarity	13/03/2011			Pass

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	Overall: Pass
<b>Asset ID: A01700</b> Description: PROSOUND MIXER Model:MMX410 Serial:0081					Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.07	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01701</b> Description: STRIP LIGHT					Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01702</b> Description: MERRY CHRISTMAS LIGHT					Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
Leakage	13/03/2011	<0.1	mA	Pass	
Load	13/03/2011	0.08	kVA	Information	
					Overall: Pass
<b>Asset ID: A21370</b> Description: 10A EXT REEL					Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.28	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
Polarity	13/03/2011			Pass	
					Overall: Pass
<b>Asset ID: A21371</b> Description: EXT LEAD					Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.12	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
Polarity	13/03/2011			Pass	
					Overall: Pass
<b>Asset ID: A21372</b> Description: EXT LEAD					Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.1	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
Polarity	13/03/2011			Pass	
					Overall: Pass
<b>Asset ID: A21373</b> Description: HOMEBASE DESKLAMP Model:GYT107 Serial:28112005					Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A21378</b> Description: CLASS2 LEAD					Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A21379</b> Description: CAMERA XFORMER					Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A21381</b> Description: SOURCE BUBBLE Machine Model:Z10					Test Instrument: 45B-0625
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.05	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass



# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	Test Instrument: 45B-0625
<b>Asset ID: A42929</b> Description: XFORMER					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A59474</b> Description: IEC LEAD 13A					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.04	Ohm	Pass	
Insulation	13/03/2011	9.46	MOhm	Fail	
					Overall: Fail
<b>Asset ID: A59475</b> Description: PEAVEY AMP					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.07	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A59476</b> Description: IEC LEAD 5A					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.05	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
Polarity	13/03/2011			Pass	
					Overall: Pass
<b>Asset ID: A59477</b> Description: URSA LASER					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.07	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A59478</b> Description: IEC LEAD 5A					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.06	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
Polarity	13/03/2011			Pass	
					Overall: Pass
<b>Asset ID: A59479</b> Description: MIXER NUMARK					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A59480</b> Description: CD PLAYER					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A59481</b> Description: SMOKE MC					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.06	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A59482</b> Description: IEC LEAD 5A					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.05	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
Polarity	13/03/2011			Pass	
					Overall: Pass

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
<b>Asset ID: A69503</b>					<b>Description: EXT LEAD</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.12	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
Polarity	13/03/2011			Pass	
					Overall: Pass
<b>Asset ID: A69504</b>					<b>Description: CLASS2 LEAD</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A69505</b>					<b>Description: AC ADAPTOR</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A81300</b>					<b>Description: RCD</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
					Overall: Pass
<b>Asset ID: A81301</b>					<b>Description: RCD</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
					Overall: Pass
<b>Asset ID: A81302</b>					<b>Description: CLASS1 LEAD</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Earth Current	13/03/2011	25	A	Information	
Earth	13/03/2011	0.05	Ohm	Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A81303</b>					<b>Description: AC ADAPTOR</b>
<b>Test Type</b>					<b>Date</b>
Visual	13/03/2011			Pass	
Insulation	13/03/2011	>99.99	MOhm	Pass	
					Overall: Pass

Total Tests: 74