



**REGISTER
OF
PORTABLE APPLIANCE TESTS**

On Behalf Of:

D &W Disco
115 Leys Road
Hemel Hempstead
Herts
HP3 9JX

Site Tested

D &W Disco
115 Leys Road
Hemel Hempstead
Herts
HP3 9JX

Date of Tests 23 Sept 2012



ISO 9001

Certificate No. FS 78965



Test Certificate



Tests Conducted By: JPS Calibration Services Ltd, Commerce House, Telford Road, Bicester, Oxfordshire, OX26 4LD

On Behalf Of: D&W Discos , 115 Leys Road, Hemel Hempstead, HP3 9JX

Site:

Location:

Number of Tests: **Number PASSED:** **Number FAILED:**

Number of Pages in Report:

Comments:

0 Fuses downrated to appropriate rating for flex csa.

The tests performed only indicate the status of the safety of the Unit Under Test and, although a functional test is performed, should not be misinterpreted as a verification of the units compliance with operational specifications. It must also be understood that some appliances (Class1) rely upon the fixed wiring of the socket to ensure continuity of the Earth connection. These Portable Appliance tests ensure the appliance under test has the correct Earth connection resistance but cannot ensure the continuity within the Fixed wiring of the supply and that Further Fixed wiring periodic tests are required.

Date of Tests:

Test Instrument:

Calibration Certificate Number:

Calibration Due Date:

Tested By:

Signed By:

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Client: D&W Discos		Site: 115 Leys Road		Location:
Asset ID: A01633	Description: IEC LEAD 5A			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01634	Description: IEC LEAD 5A			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01636	Description: IEC LEAD 5A			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01637	Description: IEC LEAD 5A			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01638	Description: IEC LEAD 10A			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01641	Description: EXT LEAD			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.12	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01647	Description: EXT LEAD			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.07	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01650	Description: 1.5M IEC ADAPTOR FLEX			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.09	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01651	Description: IEC ADAPTOR FLEX 3M			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.15	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01652 Description: 4M IEC ADAPTOR FLEX Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.2	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01653 Description: CD XFORMER Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01654 Description: IEC LEAD 5A Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.06	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01655 Description: EXT REEL 12M Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.23	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01656 Description: EXT REEL 25M Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.44	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01657 Description: SOUNDLAB MUSHROOM LIGHT Model:SRL448 Serial:03060 Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.07	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Leakage	23/09/2012	<0.1	mA	Pass
Load	23/09/2012	0.58	kVA	Information
Overall: Pass				
Asset ID: A01659 Description: FLOWER EFFECT LIGHT Model:150-283UK Serial:213000 Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.06	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01662 Description: CLASS2 LEAD Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01663 Description: LAPTOP XFORMER Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Leakage	23/09/2012	<0.1	mA	Pass
Load	23/09/2012	<0.05	kVA	Information
Overall: Pass				

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A01664					Test Instrument: 45B-0625
Description: RADIOMIC					
Test Type	Date	Result	Unit	Status	
Visual	23/09/2012			Pass	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Leakage	23/09/2012	<0.1	mA	Pass	
Load	23/09/2012	<0.05	kVA	Information	
Overall: Pass					
Asset ID: A01665					Test Instrument: 45B-0625
Description: 4 WAY CHASER LIGHT Model L70AK Serial:1680306073-					
Test Type	Date	Result	Unit	Status	
Visual	23/09/2012			Pass	
Earth Current	23/09/2012	25	A	Information	
Earth	23/09/2012	0.04	Ohm	Pass	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A01666					Test Instrument: 45B-0625
Description: INTERM POWER AMP Model:M700 Serial:011016283					
Test Type	Date	Result	Unit	Status	
Visual	23/09/2012			Pass	
Earth Current	23/09/2012	25	A	Information	
Earth	23/09/2012	0.05	Ohm	Pass	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A01667					Test Instrument: 45B-0625
Description: SOUNDLABS AMPLIFIER Model:SP6 Serial:K0006221					
Test Type	Date	Result	Unit	Status	
Visual	23/09/2012			Pass	
Earth Current	23/09/2012	25	A	Information	
Earth	23/09/2012	0.06	Ohm	Pass	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A01669					Test Instrument: 45B-0625
Description: NJD DISCO LIGHT Model: DATAMOON Serial:452101213					
Test Type	Date	Result	Unit	Status	
Earth Current	23/09/2012	25	A	Information	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Earth	23/09/2012	0.16	Ohms	Pass	
Visual	23/09/2012			Pass	
Overall: Pass					
Asset ID: A01670					Test Instrument: 45B-0625
Description: NJD DISCO LIGHT Model:DATAMOON Serial:452101271					
Test Type	Date	Result	Unit	Status	
Visual	23/09/2012			Pass	
Earth Current	23/09/2012	25	A	Information	
Earth	23/09/2012	0.13	Ohm	Pass	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A01671					Test Instrument: 45B-0625
Description: ACME EXERCET Model:MH-270M Serial:AE-02030678					
Test Type	Date	Result	Unit	Status	
Visual	23/09/2012			Pass	
Earth Current	23/09/2012	25	A	Information	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Earth	23/09/2012	0.12	Ohms	Pass	
Overall: Pass					
Asset ID: A01672					Test Instrument: 45B-0625
Description: ACME EXERCET Model:MH-270M Serial:08020122					
Test Type	Date	Result	Unit	Status	
Visual	23/09/2012			Pass	
Earth Current	23/09/2012	25	A	Information	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Earth	23/09/2012	0.11	Ohms	Pass	
Overall: Pass					
Asset ID: A01673					Test Instrument: 45B-0625
Description: SOUNDLABS WHITE LIGHT Model:DK008 Serial: 04040001					
Test Type	Date	Result	Unit	Status	
Visual	23/09/2012			Pass	
Earth Current	23/09/2012	25	A	Information	
Earth	23/09/2012	0.06	Ohm	Pass	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A01679					Test Instrument: 45B-0625
Description: ACME AUTOMATED LUMINAIRE THE WINNER Serial:PL1204					
Test Type	Date	Result	Unit	Status	
Visual	23/09/2012			Pass	
Earth Current	23/09/2012	25	A	Information	
Earth	23/09/2012	0.07	Ohm	Pass	

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01680				
Description: ACME AUTOMATED LUMINAIRE THE WINNER Serial:PL1204				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.07	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01681				
Description: IEC LEAD 5A				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	<0.04	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01684				
Description: IEC LEAD 5A				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01685				
Description: ACME DMX LIGHT Model:MH275R Serial:PL09050936				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01686				
Description: IEC LEAD 5A				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.04	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01687				
Description: ACME DMX LIGHT Model:MH-275R Serial:PL09050915				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.06	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01688				
Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.09	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01689				
Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.08	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01690				
Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:090				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.06	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Asset ID: A01691 Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.07	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01692 Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01693 Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01694 Description: IEC LEAD 5A Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.07	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01695 Description: KAM MIXER Model:GMX5 MK2 Serial:9924591 Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.15	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01696 Description: CITRONIC CD UNIT Model:CD2 Serial:K171 B110A 0036 Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.08	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01697 Description: CLASS2 LEAD Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01698 Description: NEWMARK CD UNIT Model:CDN22 Serial:H0311216610437 Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Leakage	23/09/2012	<0.1	mA	Pass
Load	23/09/2012	<0.05	kVA	Information
Overall: Pass				
Asset ID: A01699 Description: IEC LEAD 5A Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A01700 Description: PROSOUND MIXER Model:MMX410 Serial:0081 Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.07	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01702				
Description: MERRY CHRISTMAS LIGHT				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Leakage	23/09/2012	<0.1	mA	Pass
Load	23/09/2012	0.08	kVA	Information
Overall: Pass				
Asset ID: A109084				
Description: IEC ADAPTOR				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.09	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A109085				
Description: IEC LEAD 5A				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.06	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A109086				
Description: IEC LEAD 5A				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.06	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A109087				
Description: LAMP				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Insulation	23/09/2012	>99.99	MOhm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Earth	23/09/2012	0.13	Ohms	Pass
Overall: Pass				
Asset ID: A109088				
Description: LAMP				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.1	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A109089				
Description: IEC LEAD 5A				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	<0.04	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A109090				
Description: IEC LEAD 5A				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	<0.04	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A109091				
Description: IEC LEAD 5A				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	<0.04	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A21370				
Description: 10A EXT REEL				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.27	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A21371				
Description: EXT LEAD				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.11	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A21372				
Description: EXT LEAD				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.07	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A21373				
Description: HOMEBASE DESKLAMP Model GYT107 Serial:28112005				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A21378				
Description: CLASS2 LEAD				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A21379				
Description: CAMERA XFORMER				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Leakage	23/09/2012	<0.1	mA	Pass
Load	23/09/2012	<0.05	kVA	Information
Overall: Pass				
Asset ID: A21381				
Description: SOURCE BUBBLE Machine Model:Z10				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A42929				
Description: XFORMER				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A59475				
Description: PEAVEY AMP				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	4	A	Information
Earth	23/09/2012	0.17	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A59476				
Description: IEC LEAD 5A				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A59477				
Description: URSA LASER				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.08	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A59478				
Description: IEC LEAD 5A				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.06	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A59479				
Description: MIXER NUMARK				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	100	mA a.c.	Information
Insulation	23/09/2012	>99.99	MOhm	Pass
Leakage	23/09/2012	<0.1	mA	Pass
Load	23/09/2012	<0.05	kVA	Information
Overall: Pass				
Asset ID: A59480				
Description: CD PLAYER				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Leakage	23/09/2012	<0.1	mA	Pass
Load	23/09/2012	<0.05	kVA	Information
Overall: Pass				
Asset ID: A59481				
Description: SMOKE MC				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.07	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A59482				
Description: IEC LEAD 5A				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.05	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A69503				
Description: EXT LEAD				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Earth Current	23/09/2012	25	A	Information
Earth	23/09/2012	0.11	Ohm	Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Polarity	23/09/2012			Pass
Overall: Pass				
Asset ID: A69504				
Description: CLASS2 LEAD				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A69505				
Description: AC ADAPTOR				
Test Instrument: 45B-0625				
Test Type	Date	Result	Unit	Status
Visual	23/09/2012			Pass
Insulation	23/09/2012	>99.99	MOhm	Pass
Leakage	23/09/2012	<0.1	mA	Pass
Load	23/09/2012	<0.05	kVA	Information
Overall: Pass				

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A81302		Description: CLASS1 LEAD			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	23/09/2012			Pass	
Earth Current	23/09/2012	25	A	Information	
Earth	23/09/2012	0.06	Ohm	Pass	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Overall:				Pass	

Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A81303		Description: AC ADAPTOR			Test Instrument: 45B-0625
Test Type	Date	Result	Unit	Status	
Visual	23/09/2012			Pass	
Insulation	23/09/2012	>99.99	MOhm	Pass	
Leakage	23/09/2012	<0.1	mA	Pass	
Load	23/09/2012	<0.05	kVA	Information	
Overall:				Pass	

Total Tests: 77