



**REGISTER  
OF  
PORTABLE APPLIANCE TESTS**

**On Behalf Of:**

D&W Discos  
115 Leys Road  
Hemel Hempstead  
HP3 9JX

**Site Tested**

D&W Discos  
115 Leys Road  
Hemel Hempstead  
HP3 9JX

**Date of Tests** 18 November 2007



ISO 9001

Certificate No. FS 78965



**Test Certificate**



**Tests Conducted By:** JPS Calibration Services Ltd, Commerce House, Telford Road, Bicester, Oxfordshire, OX26 4LD

**On Behalf Of:** D&W Discos , 115 Leys Road, Hemel Hempstead, HP3 9JX

**Site:**

**Location:**

**Number of Tests:**  **Number PASSED:**  **Number FAILED**

**Number of Pages in Report:**

**Comments:**

0 Fuses downrated to appropriate rating for flex csa.

The tests performed only indicate the status of the safety of the Unit Under Test and, although a functional test is performed, should not be misinterpreted as a verification of the units compliance with operational specifications. It must also be understood that some appliances (Class1) rely upon the fixed wiring of the socket to ensure continuity of the Earth connection. These Portable Appliance tests ensure the appliance under test has the correct Earth connection resistance but cannot ensure the continuity within the Fixed wiring of the supply and that Further Fixed wiring periodic tests are required.

**Date of Tests:**

**Test Instrument:**

**Calibration Certificate Number:**

**Calibration Due Date:**

**Tested By:**

**Signed By:**

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
<b>Client: D&amp;W Discos</b>		<b>Site: 115 Leys Road</b>		<b>Location:</b>
Asset ID: A01632	Description: IEC LEAD 5A			Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.05	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Polarity	18/11/2007			Pass
Overall: Pass				
Asset ID: A01633	Description: IEC LEAD 5A			Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.05	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Polarity	18/11/2007			Pass
Overall: Pass				
Asset ID: A01634	Description: IEC LEAD 5A			Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.06	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Polarity	18/11/2007			Pass
Overall: Pass				
Asset ID: A01635	Description: IEC LEAD 5A			Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.06	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Polarity	18/11/2007			Pass
Overall: Pass				
Asset ID: A01636	Description: IEC LEAD 5A			Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.06	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Polarity	18/11/2007			Pass
Overall: Pass				
Asset ID: A01637	Description: IEC LEAD 5A			Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.05	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Polarity	18/11/2007			Pass
Overall: Pass				
Asset ID: A01638	Description: IEC LEAD 10A			Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.05	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Polarity	18/11/2007			Pass
Overall: Pass				
Asset ID: A01639	Description: IEC LEAD 5A			Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.05	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Polarity	18/11/2007			Pass
Overall: Pass				
Asset ID: A01641	Description: EXT LEAD			Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.08	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	Overall: Pass
<b>Asset ID: A01642</b> Description: EXT LEAD					Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.05	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01643</b> Description: EXT LEAD					Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.04	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01647</b> Description: EXT LEAD					Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	<0.04	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01649</b> Description: EXT LEAD					Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	<0.04	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01650</b> Description: 1.5M IEC ADAPTOR FLEX					Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.1	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Polarity	18/11/2007			Pass	
					Overall: Pass
<b>Asset ID: A01651</b> Description: IEC ADAPTOR FLEX 3M					Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.18	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Polarity	18/11/2007			Pass	
					Overall: Pass
<b>Asset ID: A01652</b> Description: 4M IEC ADAPTOR FLEX					Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.22	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Polarity	18/11/2007			Pass	
					Overall: Pass
<b>Asset ID: A01653</b> Description: CD XFORMER					Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	18/11/2007			Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01654</b> Description: IEC LEAD 5A					Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.06	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Polarity	18/11/2007			Pass	
					Overall: Pass
<b>Asset ID: A01655</b> Description: EXT REEL 12M					Test Instrument: V50-0140
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	18/11/2007			Pass	

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.19	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
				Overall: Pass

Asset ID: A01656 Description: EXT REEL 25M Test Instrument: V50-0140				
Test Type	Date	Result	Unit	Status
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Insulation	18/11/2007	>99.99	MOhm	Pass
Earth	18/11/2007	0.39	Ohms	Pass
				Overall: Pass

Asset ID: A01657 Description: SOUNDLAB MUSHROOM LIGHT Model:SRL448 Serial:03060 Test Instrument: V50-0140				
Test Type	Date	Result	Unit	Status
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.07	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
				Overall: Pass

Asset ID: A01658 Description: SKYTEC MUSHROOM LIGHT Model:TL-007 Serial:1680103 Test Instrument: V50-0140				
Test Type	Date	Result	Unit	Status
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.09	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
				Overall: Pass

Asset ID: A01659 Description: FLOWER EFFECT LIGHT Model:150-283UK Serial:213000 Test Instrument: V50-0140				
Test Type	Date	Result	Unit	Status
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.05	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
				Overall: Pass

Asset ID: A01661 Description: SOUNDLABS HAZE Machine Model HG002GE Test Instrument: V50-0140				
Test Type	Date	Result	Unit	Status
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.09	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
				Overall: Pass

Asset ID: A01662 Description: CLASS2 LEAD Test Instrument: V50-0140				
Test Type	Date	Result	Unit	Status
Visual	18/11/2007			Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
				Overall: Pass

Asset ID: A01663 Description: LAPTOP XFORMER Test Instrument: V50-0140				
Test Type	Date	Result	Unit	Status
Visual	18/11/2007			Pass
Leakage	18/11/2007	<0.1	mA	Pass
Load	18/11/2007	<0.05	kVA	Information
				Overall: Pass

Asset ID: A01664 Description: RADIOMIC Test Instrument: V50-0140				
Test Type	Date	Result	Unit	Status
Visual	18/11/2007			Pass
Leakage	18/11/2007	<0.1	mA	Pass
Load	18/11/2007	<0.05	kVA	Information
				Overall: Pass

Asset ID: A01665 Description: 4 WAY CHASER LIGHT Model L70AK Serial:1680306073- Test Instrument: V50-0140				
Test Type	Date	Result	Unit	Status
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.04	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
				Overall: Pass

Asset ID: A01666 Description: INTERM POWER AMP Model:M700 Serial:011016283 Test Instrument: V50-0140				
Test Type	Date	Result	Unit	Status
Visual	18/11/2007			Pass
Earth Current	18/11/2007	4	A	Information
Earth	18/11/2007	0.11	Ohm	Pass
Leakage	18/11/2007	<0.1	mA	Pass

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Load	18/11/2007	<0.05	kVA	Information
Overall: Pass				
<b>Asset ID: A01667</b>				
<b>Description: SOUNDLABS AMPLIFIER Model:SP6 Serial:K0006221</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	4	A	Information
Earth	18/11/2007	0.22	Ohm	Pass
Leakage	18/11/2007	<0.1	mA	Pass
Load	18/11/2007	0.06	kVA	Information
Overall: Pass				
<b>Asset ID: A01669</b>				
<b>Description: NJD DISCO LIGHT Model: DATAMOON Serial:452101213</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.09	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01670</b>				
<b>Description: NJD DISCO LIGHT Model:DATAMOON Serial:452101271</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.13	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01671</b>				
<b>Description: ACME EXERCET Model:MH-270M Serial:AE-02030678</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.09	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01672</b>				
<b>Description: ACME EXERCET Model:MH-270M Serial:08020122</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	4	A	Information
Earth	18/11/2007	0.05	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01673</b>				
<b>Description: SOUNDLABS WHITE LIGHT Model:DK008 Serial: 04040001</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.05	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01679</b>				
<b>Description: ACME AUTOMATED LUMINAIRE THE WINNER Serial:PL1204</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.11	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01680</b>				
<b>Description: ACME AUTOMATED LUMINAIRE THE WINNER Serial:PL1204</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.1	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01681</b>				
<b>Description: IEC LEAD 5A</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	<0.04	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Polarity	18/11/2007			Pass
Overall: Pass				

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
<b>Asset ID: A01684</b>					<b>Description: IEC LEAD 5A</b>
<b>Test Type</b>					<b>Test Instrument: V50-0140</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.05	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Polarity	18/11/2007			Pass	
					Overall: Pass
<b>Asset ID: A01685</b>					<b>Description: ACME DMX LIGHT Model:MH275R Serial:PL09050936</b>
<b>Test Type</b>					<b>Test Instrument: V50-0140</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.08	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01686</b>					<b>Description: IEC LEAD 5A</b>
<b>Test Type</b>					<b>Test Instrument: V50-0140</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.04	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Polarity	18/11/2007			Pass	
					Overall: Pass
<b>Asset ID: A01687</b>					<b>Description: ACME DMX LIGHT Model:MH-275R Serial:PL09050915</b>
<b>Test Type</b>					<b>Test Instrument: V50-0140</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.06	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01688</b>					<b>Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041</b>
<b>Test Type</b>					<b>Test Instrument: V50-0140</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.12	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01689</b>					<b>Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041</b>
<b>Test Type</b>					<b>Test Instrument: V50-0140</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.1	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01690</b>					<b>Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:090</b>
<b>Test Type</b>					<b>Test Instrument: V50-0140</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.08	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01691</b>					<b>Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09</b>
<b>Test Type</b>					<b>Test Instrument: V50-0140</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.09	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01692</b>					<b>Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09</b>
<b>Test Type</b>					<b>Test Instrument: V50-0140</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.08	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01693</b>					<b>Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09</b>
<b>Test Type</b>					<b>Test Instrument: V50-0140</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.06	Ohm	Pass	

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Insulation	18/11/2007	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01694</b>				
<b>Description: IEC LEAD 5A</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.06	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Polarity	18/11/2007			Pass
Overall: Pass				
<b>Asset ID: A01695</b>				
<b>Description: KAM MIXER Model:GMX5 MK2 Serial:9924591</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	4	A	Information
Earth	18/11/2007	0.14	Ohm	Pass
Leakage	18/11/2007	<0.1	mA	Pass
Load	18/11/2007	<0.05	kVA	Information
Overall: Pass				
<b>Asset ID: A01696</b>				
<b>Description: CITRONIC CD UNIT Model:CD2 Serial:K171 B110A 0036</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	4	A	Information
Earth	18/11/2007	0.17	Ohm	Pass
Leakage	18/11/2007	<0.1	mA	Pass
Load	18/11/2007	<0.05	kVA	Information
Overall: Pass				
<b>Asset ID: A01697</b>				
<b>Description: CLASS2 LEAD</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01698</b>				
<b>Description: NEWMARK CD UNIT Model:CDN22 Serial:H0311216610437</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Leakage	18/11/2007	<0.1	mA	Pass
Load	18/11/2007	<0.05	kVA	Information
Overall: Pass				
<b>Asset ID: A01699</b>				
<b>Description: IEC LEAD 5A</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.05	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Polarity	18/11/2007			Pass
Overall: Pass				
<b>Asset ID: A01700</b>				
<b>Description: PROSOUND MIXER Model:MMX410 Serial:0081</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	4	A	Information
Earth	18/11/2007	0.05	Ohm	Pass
Leakage	18/11/2007	<0.1	mA	Pass
Load	18/11/2007	<0.05	kVA	Information
Overall: Pass				
<b>Asset ID: A01702</b>				
<b>Description: MERRY CHRISTMAS LIGHT</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Leakage	18/11/2007	<0.1	mA	Pass
Load	18/11/2007	0.05	kVA	Information
Overall: Pass				
<b>Asset ID: A21370</b>				
<b>Description: 10A EXT REEL</b>				
<b>Test Instrument: V50-0140</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	18/11/2007			Pass
Earth Current	18/11/2007	25	A	Information
Earth	18/11/2007	0.22	Ohm	Pass
Insulation	18/11/2007	>99.99	MOhm	Pass
Overall: Pass				



# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
<b>Asset ID: A21371</b>					<b>Description: EXT LEAD</b>
<b>Test Type</b>					<b>Date</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.08	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Overall: Pass					Test Instrument: V50-0140
<b>Asset ID: A21372</b>					<b>Description: EXT LEAD</b>
<b>Test Type</b>					<b>Date</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.04	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Overall: Pass					Test Instrument: V50-0140
<b>Asset ID: A21373</b>					<b>Description: HOMEBASE DESKLAMP Model GYT107 Serial:28112005</b>
<b>Test Type</b>					<b>Date</b>
Visual	18/11/2007			Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Overall: Pass					Test Instrument: V50-0140
<b>Asset ID: A21374</b>					<b>Description: GEMINI AMPLIFIER Model XPB1600</b>
<b>Test Type</b>					<b>Date</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	4	A	Information	
Earth	18/11/2007	0.09	Ohm	Pass	
Leakage	18/11/2007	<0.1	mA	Pass	
Load	18/11/2007	<0.05	kVA	Information	
Overall: Pass					Test Instrument: V50-0140
<b>Asset ID: A21377</b>					<b>Description: RADIO MIC XFORMER</b>
<b>Test Type</b>					<b>Date</b>
Visual	18/11/2007			Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Overall: Pass					Test Instrument: V50-0140
<b>Asset ID: A21378</b>					<b>Description: CLASS2 LEAD</b>
<b>Test Type</b>					<b>Date</b>
Visual	18/11/2007			Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Overall: Pass					Test Instrument: V50-0140
<b>Asset ID: A21379</b>					<b>Description: CAMERA XFORMER</b>
<b>Test Type</b>					<b>Date</b>
Visual	18/11/2007			Pass	
Leakage	18/11/2007	<0.1	mA	Pass	
Load	18/11/2007	<0.05	kVA	Information	
Overall: Pass					Test Instrument: V50-0140
<b>Asset ID: A21381</b>					<b>Description: SOURCE BUBBLE Machine Model:Z10</b>
<b>Test Type</b>					<b>Date</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.06	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Overall: Pass					Test Instrument: V50-0140
<b>Asset ID: A42926</b>					<b>Description: IEC LEAD 5A</b>
<b>Test Type</b>					<b>Date</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.06	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Polarity	18/11/2007			Pass	
Overall: Pass					Test Instrument: V50-0140
<b>Asset ID: A42928</b>					<b>Description: SNOW MC</b>
<b>Test Type</b>					<b>Date</b>
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	0.07	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
Overall: Pass					Test Instrument: V50-0140

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
<b>Asset ID: A42929</b>		<b>Description: XFORMER</b>			<b>Test Instrument: V50-0140</b>
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	18/11/2007			Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A42930</b>		<b>Description: SMOKE MC</b>			<b>Test Instrument: V50-0140</b>
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	18/11/2007			Pass	
Earth Current	18/11/2007	25	A	Information	
Earth	18/11/2007	<0.04	Ohm	Pass	
Insulation	18/11/2007	>99.99	MOhm	Pass	
					Overall: Pass

Total Tests: 69