



**REGISTER
OF
PORTABLE APPLIANCE TESTS**

On Behalf Of:

D &W Disco
115 Leys Road
Hemel Hempstead
Herts
HP3 9JX

Site Tested

D &W Disco
115 Leys Road
Hemel Hempstead
Herts
HP3 9JX

Date of Tests 18 January 2009



ISO 9001

Certificate No. FS 78965



Test Certificate



Tests Conducted By: JPS Calibration Services Ltd, Commerce House, Telford Road, Bicester, Oxfordshire, OX26 4LD

On Behalf Of: D&W Discos , 115 Leys Road, Hemel Hempstead, HP3 9JX

Site:

Location:

Number of Tests: **Number PASSED:** **Number FAILED**

Number of Pages in Report:

Comments:

0 Fuses downrated to appropriate rating for flex csa.

The tests performed only indicate the status of the safety of the Unit Under Test and, although a functional test is performed, should not be misinterpreted as a verification of the units compliance with operational specifications. It must also be understood that some appliances (Class1) rely upon the fixed wiring of the socket to ensure continuity of the Earth connection. These Portable Appliance tests ensure the appliance under test has the correct Earth connection resistance but cannot ensure the continuity within the Fixed wiring of the supply and that Further Fixed wiring periodic tests are required.

Date of Tests:

Test Instrument:

Calibration Certificate Number:

Calibration Due Date:

Tested By:

Signed By:

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Client: D&W Discos		Site: 115 Leys Road		Location:
Asset ID: A01632	Description: IEC LEAD 5A			Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.05	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01633	Description: IEC LEAD 5A			Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.05	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01634	Description: IEC LEAD 5A			Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.05	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01635	Description: IEC LEAD 5A			Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.06	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01636	Description: IEC LEAD 5A			Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.06	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01637	Description: IEC LEAD 5A			Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.05	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01638	Description: IEC LEAD 10A			Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.05	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01639	Description: IEC LEAD 5A			Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.05	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01641	Description: EXT LEAD			Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.13	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01642		Description: EXT LEAD		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.1	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01643		Description: EXT LEAD		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.08	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01647		Description: EXT LEAD		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.09	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01649		Description: EXT LEAD		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.08	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01650		Description: 1.5M IEC ADAPTOR FLEX		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.11	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01651		Description: IEC ADAPTOR FLEX 3M		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.16	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01652		Description: 4M IEC ADAPTOR FLEX		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.2	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01653		Description: CD XFORMER		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01654		Description: IEC LEAD 5A		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.06	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01655				
Description: EXT REEL 12M				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.24	Ohm	Pass
Earth	18/01/2009	0.24	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01656				
Description: EXT REEL 25M				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.43	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass
Overall: Pass				
Asset ID: A01657				
Description: SOUNDLAB MUSHROOM LIGHT Model:SRL448 Serial:03060				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.07	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01658				
Description: SKYTEC MUSHROOM LIGHT Model:TL-007 Serial:1680103				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.07	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01659				
Description: FLOWER EFFECT LIGHT Model:150-283UK Serial:213000				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.06	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01661				
Description: SOUNDLABS HAZE Machine Model HG002GE				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.08	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01662				
Description: CLASS2 LEAD				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01663				
Description: LAPTOP XFORMER				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01664				
Description: RADIOMIC				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Leakage	18/01/2009	<0.1	mA	Pass
Load	18/01/2009	<0.05	kVA	Information
Overall: Pass				
Asset ID: A01665				
Description: 4 WAY CHASER LIGHT Model L70AK Serial:1680306073-				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.04	Ohm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01666				
Description: INTERM POWER AMP Model:M700 Serial:011016283				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	4	A	Information
Earth	18/01/2009	0.06	Ohm	Pass
Substitute Leakage	18/01/2009	<0.1	mA	Pass
Leakage	18/01/2009	<0.1	mA	Pass
Load	18/01/2009	<0.05	kVA	Information
Overall: Pass				
Asset ID: A01667				
Description: SOUNDLABS AMPLIFIER Model:SP6 Serial:K0006221				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	4	A	Information
Earth	18/01/2009	0.16	Ohm	Pass
Substitute Leakage	18/01/2009	<0.1	mA	Pass
Leakage	18/01/2009	<0.1	mA	Pass
Load	18/01/2009	0.06	kVA	Information
Overall: Pass				
Asset ID: A01669				
Description: NJD DISCO LIGHT Model: DATAMOON Serial:452101213				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.09	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01670				
Description: NJD DISCO LIGHT Model:DATAMOON Serial:452101271				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.08	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01671				
Description: ACME EXERCET Model:MH-270M Serial:AE-02030678				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.1	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01672				
Description: ACME EXERCET Model:MH-270M Serial:08020122				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.05	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01673				
Description: SOUNDLABS WHITE LIGHT Model:DK008 Serial: 04040001				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.05	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01679				
Description: ACME AUTOMATED LUMINAIRE THE WINNER Serial:PL1204				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.09	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01680				
Description: ACME AUTOMATED LUMINAIRE THE WINNER Serial:PL1204				
Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.08	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A01681					Description: IEC LEAD 5A
Test Type					Date
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.04	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Polarity	18/01/2009			Pass	
					Overall: Pass
Asset ID: A01684					Description: IEC LEAD 5A
Test Type					Date
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.05	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Polarity	18/01/2009			Pass	
					Overall: Pass
Asset ID: A01685					Description: ACME DMX LIGHT Model:MH275R Serial:PL09050936
Test Type					Date
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.05	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01686					Description: IEC LEAD 5A
Test Type					Date
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.04	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Polarity	18/01/2009			Pass	
					Overall: Pass
Asset ID: A01687					Description: ACME DMX LIGHT Model:MH-275R Serial:PL09050915
Test Type					Date
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.11	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01688					Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041
Test Type					Date
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.11	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01689					Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041
Test Type					Date
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.1	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01690					Description: ACME AUTOMATED LUMINARE SUPER SCIMITAR Serial:090
Test Type					Date
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.07	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01691					Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09
Test Type					Date
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.08	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01692					Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09
Test Type					Date
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Earth	18/01/2009	0.06	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Overall: Pass				

Asset ID: A01693	Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09				Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.05	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Overall: Pass					

Asset ID: A01694	Description: IEC LEAD 5A				Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.06	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Polarity	18/01/2009			Pass	
Overall: Pass					

Asset ID: A01695	Description: KAM MIXER Model:GMX5 MK2 Serial:9924591				Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	100	mA a.c.	Information	
Earth	18/01/2009	0.05	Ohm	Pass	
Substitute Leakage	18/01/2009	<0.1	mA	Pass	
Leakage	18/01/2009	<0.1	mA	Pass	
Load	18/01/2009	<0.05	kVA	Information	
Overall: Pass					

Asset ID: A01696	Description: CITRONIC CD UNIT Model:CD2 Serial:K171 B110A 0036				Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	100	mA a.c.	Information	
Earth	18/01/2009	0.28	Ohm	Pass	
Leakage	18/01/2009	<0.1	mA	Pass	
Load	18/01/2009	<0.05	kVA	Information	
Overall: Pass					

Asset ID: A01697	Description: CLASS2 LEAD				Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Overall: Pass					

Asset ID: A01698	Description: NEWMARK CD UNIT Model:CDN22 Serial:H0311216610437				Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Leakage	18/01/2009	<0.1	mA	Pass	
Load	18/01/2009	<0.05	kVA	Information	
Overall: Pass					

Asset ID: A01699	Description: IEC LEAD 5A				Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.05	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Polarity	18/01/2009			Pass	
Overall: Pass					

Asset ID: A01700	Description: PROSOUND MIXER Model:MMX410 Serial:0081				Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	100	mA a.c.	Information	
Earth	18/01/2009	0.06	Ohm	Pass	
Leakage	18/01/2009	<0.1	mA	Pass	
Load	18/01/2009	<0.05	kVA	Information	
Overall: Pass					

Asset ID: A01701	Description: STRIP LIGHT				Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Leakage	18/01/2009	<0.1	mA	Pass	
Load	18/01/2009	<0.05	kVA	Information	
Overall: Pass					

Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A01702					Test Instrument: W41-0982
Description: MERRY CHRISTMAS LIGHT					
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Leakage	18/01/2009	<0.1	mA	Pass	
Load	18/01/2009	0.08	kVA	Information	
Overall: Pass					
Asset ID: A21370					Test Instrument: W41-0982
Description: 10A EXT REEL					
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.28	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Polarity	18/01/2009			Pass	
Overall: Pass					
Asset ID: A21371					Test Instrument: W41-0982
Description: EXT LEAD					
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.13	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Polarity	18/01/2009			Pass	
Overall: Pass					
Asset ID: A21372					Test Instrument: W41-0982
Description: EXT LEAD					
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.09	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Polarity	18/01/2009			Pass	
Overall: Pass					
Asset ID: A21373					Test Instrument: W41-0982
Description: HOMEBASE DESKLAMP Model GYT107 Serial:28112005					
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Leakage	18/01/2009	<0.1	mA	Pass	
Load	18/01/2009	<0.05	kVA	Information	
Overall: Pass					
Asset ID: A21381					Test Instrument: W41-0982
Description: SOURCE BUBBLE Machine Model:Z10					
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.09	Ohm	Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A42929					Test Instrument: W41-0982
Description: XFORMER					
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Insulation	18/01/2009	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A59474					Test Instrument: W41-0982
Description: IEC LEAD 13A					
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	25	A	Information	
Earth	18/01/2009	0.04	Ohm	Pass	
Insulation	18/01/2009	21.94	MOhm	Pass	
Polarity	18/01/2009			Pass	
Overall: Pass					
Asset ID: A59475					Test Instrument: W41-0982
Description: PEAVEY AMP					
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	
Earth Current	18/01/2009	4	A	Information	
Earth	18/01/2009	0.1	Ohm	Pass	
Substitute Leakage	18/01/2009	<0.1	mA	Pass	
Leakage	18/01/2009	<0.1	mA	Pass	
Load	18/01/2009	<0.05	kVA	Information	
Overall: Pass					
Asset ID: A59476					Test Instrument: W41-0982
Description: IEC LEAD 5A					
Test Type	Date	Result	Unit	Status	
Visual	18/01/2009			Pass	

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.05	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass

Overall: Pass

Asset ID: A59477	Description: URSA LASER				Test Instrument: W41-0982
------------------	-------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	4	A	Information
Earth	18/01/2009	0.07	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass

Overall: Pass

Asset ID: A59478	Description: IEC LEAD 5A				Test Instrument: W41-0982
------------------	--------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.06	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass

Overall: Pass

Asset ID: A59479	Description: MIXER NUMARK				Test Instrument: W41-0982
------------------	---------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Substitute Leakage	18/01/2009	<0.1	mA	Pass
Leakage	18/01/2009	<0.1	mA	Pass
Load	18/01/2009	<0.05	kVA	Information

Overall: Pass

Asset ID: A59480	Description: CD PLAYER				Test Instrument: W41-0982
------------------	------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Substitute Leakage	18/01/2009	<0.1	mA	Pass
Leakage	18/01/2009	<0.1	mA	Pass
Load	18/01/2009	<0.05	kVA	Information

Overall: Pass

Asset ID: A59481	Description: SMOKE MC				Test Instrument: W41-0982
------------------	-----------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.06	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass

Overall: Pass

Asset ID: A59482	Description: IEC LEAD 5A				Test Instrument: W41-0982
------------------	--------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/01/2009			Pass
Earth Current	18/01/2009	25	A	Information
Earth	18/01/2009	0.05	Ohm	Pass
Insulation	18/01/2009	>99.99	MOhm	Pass
Polarity	18/01/2009			Pass

Overall: Pass

Total Tests: 72