



**REGISTER
OF
PORTABLE APPLIANCE TESTS**

On Behalf Of:

D &W Disco
115 Leys Road
Hemel Hempstead
Herts
HP3 9JX

Site Tested

D &W Disco
115 Leys Road
Hemel Hempstead
Herts
HP3 9JX

Date of Tests 28 February 2010



ISO 9001

Certificate No. FS 78965



Test Certificate



Tests Conducted By: JPS Calibration Services Ltd, Commerce House, Telford Road, Bicester, Oxfordshire, OX26 4LD

On Behalf Of: D&W Discos , 115 Leys Road, Hemel Hempstead, HP3 9JX

Site:

Location:

Number of Tests: **Number PASSED:** **Number FAILED:**

Number of Pages in Report:

Comments:

0 Fuses downrated to appropriate rating for flex csa.

The tests performed only indicate the status of the safety of the Unit Under Test and, although a functional test is performed, should not be misinterpreted as a verification of the units compliance with operational specifications. It must also be understood that some appliances (Class1) rely upon the fixed wiring of the socket to ensure continuity of the Earth connection. These Portable Appliance tests ensure the appliance under test has the correct Earth connection resistance but cannot ensure the continuity within the Fixed wiring of the supply and that Further Fixed wiring periodic tests are required.

Date of Tests:

Test Instrument:

Calibration Certificate Number:

Calibration Due Date:

Tested By:

Signed By:

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Client: D&W Discos		Site: 115 Leys Road		Location:
Asset ID: A01632		Description: IEC LEAD 5A		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.04	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
Overall: Pass				
Asset ID: A01633		Description: IEC LEAD 5A		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.05	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
Overall: Pass				
Asset ID: A01634		Description: IEC LEAD 5A		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.04	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
Overall: Pass				
Asset ID: A01635		Description: IEC LEAD 5A		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.05	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
Overall: Pass				
Asset ID: A01636		Description: IEC LEAD 5A		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.05	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
Overall: Pass				
Asset ID: A01637		Description: IEC LEAD 5A		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.04	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
Overall: Pass				
Asset ID: A01638		Description: IEC LEAD 10A		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.05	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
Overall: Pass				
Asset ID: A01639		Description: IEC LEAD 5A		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.05	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
Overall: Pass				
Asset ID: A01641		Description: EXT LEAD		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.11	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Polarity	28/02/2010			Pass
				Overall: Pass
Asset ID: A01642		Description: EXT LEAD		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.08	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
				Overall: Pass
Asset ID: A01647		Description: EXT LEAD		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.06	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
				Overall: Pass
Asset ID: A01650		Description: 1.5M IEC ADAPTOR FLEX		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.09	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
				Overall: Pass
Asset ID: A01651		Description: IEC ADAPTOR FLEX 3M		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.14	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
				Overall: Pass
Asset ID: A01652		Description: 4M IEC ADAPTOR FLEX		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.18	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
				Overall: Pass
Asset ID: A01653		Description: CD XFORMER		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
				Overall: Pass
Asset ID: A01655		Description: EXT REEL 12M		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.22	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
				Overall: Pass
Asset ID: A01656		Description: EXT REEL 25M		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.42	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
				Overall: Pass
Asset ID: A01657		Description: SOUNDLAB MUSHROOM LIGHT Model:SRL448 Serial:03060		Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.06	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Overall: Pass				
Asset ID: A01659 Description: FLOWER EFFECT LIGHT Model:150-283UK Serial:213000 Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.08	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01661 Description: SOUNDLABS HAZE Machine Model HG002GE Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.07	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01662 Description: CLASS2 LEAD Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01663 Description: LAPTOP XFORMER Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01664 Description: RADIOMIC Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01665 Description: 4 WAY CHASER LIGHT Model L70AK Serial:1680306073- Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.04	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01666 Description: INTERM POWER AMP Model:M700 Serial:011016283 Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	4	A	Information
Earth	28/02/2010	0.05	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01667 Description: SOUNDLABS AMPLIFIER Model:SP6 Serial:K0006221 Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	4	A	Information
Earth	28/02/2010	0.12	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01669 Description: NJD DISCO LIGHT Model: DATAMOON Serial:452101213 Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.08	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01670 Description: NJD DISCO LIGHT Model:DATAMOON Serial:452101271 Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Insulation	28/02/2010	>99.99	MOhm	Pass
Earth	28/02/2010	0.12	Ohms	Pass
Overall: Pass				
Asset ID: A01671 Description: ACME EXERCET Model:MH-270M Serial:AE-02030678 Test Instrument: W41-0982				
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.09	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
				Overall: Pass

Asset ID:	Description:	Test Instrument:		
A01672	ACME EXERCET Model:MH-270M Serial:08020122	W41-0982		
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.05	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
				Overall: Pass

Asset ID:	Description:	Test Instrument:		
A01673	SOUNDLABS WHITE LIGHT Model:DK008 Serial: 04040001	W41-0982		
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.05	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
				Overall: Pass

Asset ID:	Description:	Test Instrument:		
A01679	ACME AUTOMATED LUMINAIRE THE WINNER Serial:PL1204	W41-0982		
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	10	A	Information
Earth	28/02/2010	0.07	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
				Overall: Pass

Asset ID:	Description:	Test Instrument:		
A01680	ACME AUTOMATED LUMINAIRE THE WINNER Serial:PL1204	W41-0982		
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	10	A	Information
Earth	28/02/2010	0.07	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
				Overall: Pass

Asset ID:	Description:	Test Instrument:		
A01681	IEC LEAD 5A	W41-0982		
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	<0.04	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
				Overall: Pass

Asset ID:	Description:	Test Instrument:		
A01684	IEC LEAD 5A	W41-0982		
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.04	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
				Overall: Pass

Asset ID:	Description:	Test Instrument:		
A01685	ACME DMX LIGHT Model:MH275R Serial:PL09050936	W41-0982		
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	10	A	Information
Earth	28/02/2010	0.06	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
				Overall: Pass

Asset ID:	Description:	Test Instrument:		
A01686	IEC LEAD 5A	W41-0982		
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	25	A	Information
Earth	28/02/2010	0.04	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass
Polarity	28/02/2010			Pass
				Overall: Pass

Asset ID:	Description:	Test Instrument:		
A01687	ACME DMX LIGHT Model:MH-275R Serial:PL09050915	W41-0982		
Test Type	Date	Result	Unit	Status
Visual	28/02/2010			Pass
Earth Current	28/02/2010	10	A	Information
Earth	28/02/2010	0.05	Ohm	Pass
Insulation	28/02/2010	>99.99	MOhm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	Overall: Pass
Asset ID: A01688 Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041 Test Instrument: W41-0982					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.08	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01689 Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041 Test Instrument: W41-0982					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.07	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01690 Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:090 Test Instrument: W41-0982					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	10	A	Information	
Earth	28/02/2010	0.06	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01691 Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 Test Instrument: W41-0982					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	10	A	Information	
Earth	28/02/2010	0.08	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01692 Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 Test Instrument: W41-0982					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.05	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01693 Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 Test Instrument: W41-0982					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.05	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01694 Description: IEC LEAD 5A Test Instrument: W41-0982					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.06	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Polarity	28/02/2010			Pass	
					Overall: Pass
Asset ID: A01695 Description: KAM MIXER Model:GMX5 MK2 Serial:9924591 Test Instrument: W41-0982					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01696 Description: CITRONIC CD UNIT Model:CD2 Serial:K171 B110A 0036 Test Instrument: W41-0982					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	4	A	Information	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Earth	28/02/2010	0.12	Ohms	Pass	
					Overall: Pass
Asset ID: A01697 Description: CLASS2 LEAD Test Instrument: W41-0982					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A01698					Test Instrument: W41-0982
Description: NEWMARK CD UNIT Model:CDN22 Serial:H0311216610437					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01699					Test Instrument: W41-0982
Description: IEC LEAD 5A					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.04	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Polarity	28/02/2010			Pass	
					Overall: Pass
Asset ID: A01700					Test Instrument: W41-0982
Description: PROSOUND MIXER Model:MMX410 Serial:0081					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	4	A	Information	
Earth	28/02/2010	0.16	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A01701					Test Instrument: W41-0982
Description: STRIP LIGHT					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Leakage	28/02/2010	<0.1	mA	Pass	
Load	28/02/2010	<0.05	kVA	Information	
					Overall: Pass
Asset ID: A01702					Test Instrument: W41-0982
Description: MERRY CHRISTMAS LIGHT					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Leakage	28/02/2010	<0.1	mA	Pass	
Load	28/02/2010	0.09	kVA	Information	
					Overall: Pass
Asset ID: A01754					Test Instrument: W41-0982
Description: IEC LEAD 5A					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.05	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Polarity	28/02/2010			Pass	
					Overall: Pass
Asset ID: A21370					Test Instrument: W41-0982
Description: 10A EXT REEL					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.24	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Polarity	28/02/2010			Pass	
					Overall: Pass
Asset ID: A21371					Test Instrument: W41-0982
Description: EXT LEAD					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.11	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Polarity	28/02/2010			Pass	
					Overall: Pass
Asset ID: A21372					Test Instrument: W41-0982
Description: EXT LEAD					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.08	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Polarity	28/02/2010			Pass	
					Overall: Pass
Asset ID: A21373					Test Instrument: W41-0982
Description: HOMEBASE DESKLAMP Model:GYT107 Serial:28112005					
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	

Test_Type	Test_Date	Result	Unit	Status	Overall: Pass
Asset ID: A21378 Description: CLASS2 LEAD					Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A21379 Description: CAMERA XFORMER					Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Leakage	28/02/2010	<0.1	mA	Pass	
Load	28/02/2010	<0.05	kVA	Information	
					Overall: Pass
Asset ID: A21381 Description: SOURCE BUBBLE Machine Model:Z10					Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.08	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A42929 Description: XFORMER					Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A59474 Description: IEC LEAD 13A					Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.04	Ohm	Pass	
Insulation	28/02/2010	14.17	MOhm	Pass	
Polarity	28/02/2010			Pass	
					Overall: Pass
Asset ID: A59475 Description: PEAVEY AMP					Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	4	A	Information	
Earth	28/02/2010	0.08	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A59476 Description: IEC LEAD 5A					Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.05	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Polarity	28/02/2010			Pass	
					Overall: Pass
Asset ID: A59477 Description: URSA LASER					Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	4	A	Information	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Earth	28/02/2010	0.12	Ohms	Pass	
					Overall: Pass
Asset ID: A59478 Description: IEC LEAD 5A					Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.06	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Polarity	28/02/2010			Pass	
					Overall: Pass
Asset ID: A59479 Description: MIXER NUMARK					Test Instrument: W41-0982
Test Type	Date	Result	Unit	Status	
Visual	28/02/2010			Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass



Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A59480					Description: CD PLAYER
Test Type					Date
Visual	28/02/2010			Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A59481					Description: SMOKE MC
Test Type					Date
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.06	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A59482					Description: IEC LEAD 5A
Test Type					Date
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.05	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Polarity	28/02/2010			Pass	
					Overall: Pass
Asset ID: A69503					Description: EXT LEAD
Test Type					Date
Visual	28/02/2010			Pass	
Earth Current	28/02/2010	25	A	Information	
Earth	28/02/2010	0.1	Ohm	Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
Polarity	28/02/2010			Pass	
					Overall: Pass
Asset ID: A69504					Description: CLASS2 LEAD
Test Type					Date
Visual	28/02/2010			Pass	
Insulation	28/02/2010	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A69505					Description: AC ADAPTOR
Test Type					Date
Visual	28/02/2010			Pass	
Leakage	28/02/2010	<0.1	mA	Pass	
Load	28/02/2010	<0.05	kVA	Information	
					Overall: Pass

Total Tests: 74