



**REGISTER
OF
PORTABLE APPLIANCE TESTS**

On Behalf Of:

D &W Disco
Flat 13 Wight House
Explorer Drive
Tolpits Lane
Watford
WD18 6GT

Site Tested

D &W Disco
Flat 13 Wight House
Explorer Drive
Tolpits Lane
Watford
WD18 6GT

Date of Tests 19 April 2015



Test Certificate



Tests Conducted By: JPS Calibration Services Ltd, Commerce House, Telford Road, Bicester, Oxfordshire, OX26 4LD

On Behalf Of: D&W Discos, Flat 13 Wight House, Explorer Drive, Tolpits Lane, Watford, Herts, WD18 6GT

Site: D&W Discos, Flat 13 Wight House, Explorer Drive, Tolpits Lane, Watford, Herts, WD18 6GT

Location: D&W Discos, Flat 13 Wight House, Explorer Drive, Tolpits Lane, Watford, Herts, WD18 6GT

Number of Tests: 67 Number PASSED: 67 Number FAILED: 0

Number of Pages in Report: 10

Comments:

0 Fuses downrated to appropriate rating for flex csa.

The tests performed only indicate the status of the safety of the Unit Under Test and, although a functional test is performed, should not be misinterpreted as a verification of the units compliance with operational specifications. It must also be understood that some appliances (Class1) rely upon the fixed wiring of the socket to ensure continuity of the Earth connection. These Portable Appliance tests ensure the appliance under test has the correct Earth connection resistance but cannot ensure the continuity within the Fixed wiring of the supply and that Further Fixed wiring periodic tests are required.

Date of Tests: 19 April 2015

Test Instrument: JPS0253A

Calibration Certificate Number: 15-260101

Calibration Due Date: 26 Jan 2016

Tested By: John Preston

Signed By:

Detailed Latest Test Results



| Test_Type | Test_Date | Result | Unit | Status |
|-------------------------------|------------------------------------|------------------------------|-------------|---------------------------|
| Client: D&W Discos | | Site: Flat 13 Watford | | Location: |
| Asset ID: A01633 | Description: IEC LEAD 5A | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.06 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01634 | Description: IEC LEAD 5A | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.06 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01636 | Description: IEC LEAD 5A | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.06 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01637 | Description: IEC LEAD 5A | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.06 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01638 | Description: IEC LEAD 10A | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.06 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01641 | Description: EXT LEAD | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.14 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01647 | Description: EXT LEAD | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.09 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01650 | Description: 1.5M IEC ADAPTOR FLEX | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.12 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01651 | Description: IEC ADAPTOR FLEX 3M | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.15 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |

Detailed Latest Test Results



| Test_Type | Test_Date | Result | Unit | Status |
|--|-------------|---------------|-------------|---------------|
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01652 Description: 4M IEC ADAPTOR FLEX Test Instrument: X39-0571 | | | | |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.23 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01653 Description: CD XFORMER Test Instrument: X39-0571 | | | | |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Overall: Pass | | | | |
| Asset ID: A01654 Description: IEC LEAD 5A Test Instrument: X39-0571 | | | | |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.06 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01655 Description: EXT REEL 12M Test Instrument: X39-0571 | | | | |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.25 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01656 Description: EXT REEL 25M Test Instrument: X39-0571 | | | | |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.45 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Polarity | 19/04/2015 | | | Pass |
| Overall: Pass | | | | |
| Asset ID: A01657 Description: SOUNDLAB MUSHROOM LIGHT Model:SRL448 Serial:03060 Test Instrument: X39-0571 | | | | |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.09 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Overall: Pass | | | | |
| Asset ID: A01658 Description: SKYTEC MUSHROOM LIGHT Model:TL-007 Serial:1680103 Test Instrument: X39-0571 | | | | |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.08 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Overall: Pass | | | | |
| Asset ID: A01659 Description: FLOWER EFFECT LIGHT Model:150-283UK Serial:213000 Test Instrument: X39-0571 | | | | |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | Information |
| Earth | 19/04/2015 | 0.08 | Ohm | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Overall: Pass | | | | |
| Asset ID: A01662 Description: CLASS2 LEAD Test Instrument: X39-0571 | | | | |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |
| Overall: Pass | | | | |
| Asset ID: A01663 Description: LAPTOP XFORMER Test Instrument: X39-0571 | | | | |
| Test Type | Date | Result | Unit | Status |
| Visual | 19/04/2015 | | | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass |

Detailed Latest Test Results



| Test_Type | Test_Date | Result | Unit | Status |
|---------------|------------|--------|------|-------------|
| Leakage | 19/04/2015 | <0.1 | mA | Pass |
| Load | 19/04/2015 | <0.05 | kVA | Information |
| Overall: Pass | | | | |

| Asset ID: A01664 | Description: RADIOMIC | | | | Test Instrument: X39-0571 |
|------------------|-----------------------|--------|------|--------|---------------------------|
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |

| Asset ID: A01665 | Description: 4 WAY CHASER LIGHT Model L70AK Serial:1680306073- | | | | Test Instrument: X39-0571 |
|------------------|--|--------|------|-------------|---------------------------|
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.05 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |

| Asset ID: A01667 | Description: SOUNDLABS AMPLIFIER Model:SP6 Serial:K0006221 | | | | Test Instrument: X39-0571 |
|------------------|--|--------|------|-------------|---------------------------|
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.11 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |

| Asset ID: A01669 | Description: NJD DISCO LIGHT Model: DATAMOON Serial:452101213 | | | | Test Instrument: X39-0571 |
|------------------|---|--------|------|-------------|---------------------------|
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.08 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |

| Asset ID: A01670 | Description: NJD DISCO LIGHT Model:DATAMOON Serial:452101271 | | | | Test Instrument: X39-0571 |
|------------------|--|--------|------|-------------|---------------------------|
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Earth | 19/04/2015 | 0.1 | Ohms | Pass | |
| Overall: Pass | | | | | |

| Asset ID: A01671 | Description: ACME EXERCET Model:MH-270M Serial:AE-02030678 | | | | Test Instrument: X39-0571 |
|------------------|--|--------|------|-------------|---------------------------|
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Earth | 19/04/2015 | 0.12 | Ohms | Pass | |
| Overall: Pass | | | | | |

| Asset ID: A01672 | Description: ACME EXERCET Model:MH-270M Serial:08020122 | | | | Test Instrument: X39-0571 |
|------------------|---|--------|------|-------------|---------------------------|
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.1 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |

| Asset ID: A01684 | Description: IEC LEAD 5A | | | | Test Instrument: X39-0571 |
|------------------|--------------------------|--------|------|-------------|---------------------------|
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.05 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| Overall: Pass | | | | | |

| Asset ID: A01685 | Description: ACME DMX LIGHT Model:MH275R Serial:PL09050936 | | | | Test Instrument: X39-0571 |
|------------------|--|--------|------|-------------|---------------------------|
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.07 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |

Detailed Latest Test Results



| Test_Type | Test_Date | Result | Unit | Status | |
|--|-------------|---------------|-------------|---------------|---------------------------|
| Asset ID: A01686 | | | | | Test Instrument: X39-0571 |
| Description: IEC LEAD 5A | | | | | |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.05 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A01687 | | | | | Test Instrument: X39-0571 |
| Description: ACME DMX LIGHT Model:MH-275R Serial:PL09050915 | | | | | |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.1 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A01688 | | | | | Test Instrument: X39-0571 |
| Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041 | | | | | |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Earth | 19/04/2015 | 0.12 | Ohms | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A01689 | | | | | Test Instrument: X39-0571 |
| Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041 | | | | | |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Earth | 19/04/2015 | 0.11 | Ohms | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A01690 | | | | | Test Instrument: X39-0571 |
| Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:090 | | | | | |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.07 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A01691 | | | | | Test Instrument: X39-0571 |
| Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 | | | | | |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.08 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A01692 | | | | | Test Instrument: X39-0571 |
| Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 | | | | | |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.05 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A01693 | | | | | Test Instrument: X39-0571 |
| Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 | | | | | |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.05 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A01702 | | | | | Test Instrument: X39-0571 |
| Description: MERRY CHRISTMAS LIGHT | | | | | |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A109084 | | | | | Test Instrument: X39-0571 |
| Description: IEC ADAPTOR | | | | | |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.11 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |

Detailed Latest Test Results



| Test_Type | Test_Date | Result | Unit | Status | Overall: Pass |
|--------------------------|------------|--------|------|--------|---------------------------------|
| Asset ID: A109085 | | | | | Description: IEC LEAD 5A |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | | Information |
| Earth | 19/04/2015 | 0.06 | Ohm | | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | | Pass |
| Polarity | 19/04/2015 | | | | Pass |
| | | | | | Overall: Pass |
| Asset ID: A109086 | | | | | Description: IEC LEAD 5A |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | | Information |
| Earth | 19/04/2015 | 0.07 | Ohm | | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | | Pass |
| Polarity | 19/04/2015 | | | | Pass |
| | | | | | Overall: Pass |
| Asset ID: A109087 | | | | | Description: LAMP |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | | Information |
| Earth | 19/04/2015 | 0.08 | Ohm | | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | | Pass |
| | | | | | Overall: Pass |
| Asset ID: A109088 | | | | | Description: LAMP |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | | Information |
| Earth | 19/04/2015 | 0.09 | Ohm | | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | | Pass |
| | | | | | Overall: Pass |
| Asset ID: A109089 | | | | | Description: IEC LEAD 5A |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | | Information |
| Earth | 19/04/2015 | 0.04 | Ohm | | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | | Pass |
| Polarity | 19/04/2015 | | | | Pass |
| | | | | | Overall: Pass |
| Asset ID: A109090 | | | | | Description: IEC LEAD 5A |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | | Information |
| Earth | 19/04/2015 | 0.04 | Ohm | | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | | Pass |
| Polarity | 19/04/2015 | | | | Pass |
| | | | | | Overall: Pass |
| Asset ID: A109091 | | | | | Description: IEC LEAD 5A |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | | Information |
| Earth | 19/04/2015 | <0.04 | Ohm | | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | | Pass |
| Polarity | 19/04/2015 | | | | Pass |
| | | | | | Overall: Pass |
| Asset ID: A140131 | | | | | Description: SPEAKER |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | | Information |
| Earth | 19/04/2015 | 0.07 | Ohm | | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | | Pass |
| | | | | | Overall: Pass |
| Asset ID: A140132 | | | | | Description: SPEAKER |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | | Pass |
| Earth Current | 19/04/2015 | 25 | A | | Information |
| Earth | 19/04/2015 | 0.07 | Ohm | | Pass |
| Insulation | 19/04/2015 | >99.99 | MOhm | | Pass |
| | | | | | Overall: Pass |

Detailed Latest Test Results



| Test_Type | Test_Date | Result | Unit | Status | |
|--------------------------|------------|--------|------|-------------|--|
| Asset ID: A140133 | | | | | Description: IEC LEAD 5A |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.05 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| | | | | | Overall: Pass |
| Asset ID: A140134 | | | | | Description: IEC ADAPTOR |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.08 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| | | | | | Overall: Pass |
| Asset ID: A140135 | | | | | Description: LIGHTBAR |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.08 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| | | | | | Overall: Pass |
| Asset ID: A140136 | | | | | Description: IEC LEAD 10A |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.05 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| | | | | | Overall: Pass |
| Asset ID: A140137 | | | | | Description: IEC LEAD 10A |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.05 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| | | | | | Overall: Pass |
| Asset ID: A140138 | | | | | Description: EXTENSION REEL |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.29 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| | | | | | Overall: Pass |
| Asset ID: A21371 | | | | | Description: EXT LEAD |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.14 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| | | | | | Overall: Pass |
| Asset ID: A21372 | | | | | Description: EXT LEAD |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.1 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| | | | | | Overall: Pass |
| Asset ID: A21373 | | | | | Description: HOMEBASE DESKLAMP Model GYT107 Serial:28112005 |
| Test Type | | | | | Date |
| Visual | 19/04/2015 | | | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| | | | | | Overall: Pass |

Detailed Latest Test Results



| Test_Type | Test_Date | Result | Unit | Status | |
|--------------------|-------------|---------------|-------------|---------------|---------------------------|
| Asset ID: A59475 | | | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Earth | 19/04/2015 | 0.11 | Ohms | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A59476 | | | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.05 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A59477 | | | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.09 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A59478 | | | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.07 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A59479 | | | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Substitute Leakage | 19/04/2015 | 0.1 | mA | Pass | |
| Leakage | 19/04/2015 | <0.1 | mA | Pass | |
| Leakage | 19/04/2015 | <0.1 | mA | Pass | |
| Load | 19/04/2015 | <0.05 | kVA | Information | |
| Load | 19/04/2015 | <0.05 | kVA | Information | |
| Overall: Pass | | | | | |
| Asset ID: A59480 | | | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A59481 | | | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.07 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Earth | 19/04/2015 | 0.1 | Ohms | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A59482 | | | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.06 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| Overall: Pass | | | | | |
| Asset ID: A69503 | | | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.13 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Polarity | 19/04/2015 | | | Pass | |
| Overall: Pass | | | | | |

Detailed Latest Test Results



| Test_Type | Test_Date | Result | Unit | Status | |
|-------------------------|-------------|---------------------------------|-------------|---------------|----------------------------------|
| Asset ID: A81302 | | Description: CLASS1 LEAD | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Earth Current | 19/04/2015 | 25 | A | Information | |
| Earth | 19/04/2015 | 0.07 | Ohm | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| | | | | Overall: Pass | |
| Asset ID: A81303 | | Description: AC ADAPTOR | | | Test Instrument: X39-0571 |
| Test Type | Date | Result | Unit | Status | |
| Visual | 19/04/2015 | | | Pass | |
| Insulation | 19/04/2015 | >99.99 | MOhm | Pass | |
| Leakage | 19/04/2015 | <0.1 | mA | Pass | |
| Load | 19/04/2015 | <0.05 | kVA | Information | |
| | | | | Overall: Pass | |

Total Tests: 67