



**REGISTER  
OF  
PORTABLE APPLIANCE TESTS**

**On Behalf Of:**

D &W Disco  
Flat 13 Wight House  
Explorer Drive  
Tolpits Lane  
Watford  
WD18 6GT

**Site Tested**

D &W Disco  
Flat 13 Wight House  
Explorer Drive  
Tolpits Lane  
Watford  
WD18 6GT

**Date of Tests** 16 April 2017



Test Certificate



Tests Conducted By: JPS Calibration Services Ltd, Commerce House, Telford Road, Bicester, Oxfordshire, OX26 4LD

On Behalf Of: D&W Discos , Flat 13 Wight House, Explorer Drive, Tolpits Lane, Watford, Herts, WD18 6GT

Site: D&W Discos . Flat 13 Wight House. Explorer Drive. Tolpits Lane. Watford. Herts. WD18 6GT

Location: D&W Discos . Flat 13 Wight House. Explorer Drive. Tolpits Lane. Watford. Herts. WD18 6GT

Number of Tests: 107 Number PASSED: 107 Number FAILED: 0

Number of Pages in Report: 14

Comments:

0 Fuses downrated to appropriate rating for flex csa.

The tests performed only indicate the status of the safety of the Unit Under Test and, although a functional test is performed, should not be misinterpreted as a verification of the units compliance with operational specifications. It must also be understood that some appliances (Class1) rely upon the fixed wiring of the socket to ensure continuity of the Earth connection. These Portable Appliance tests ensure the appliance under test has the correct Earth connection resistance but cannot ensure the continuity within the Fixed wiring of the supply and that Further Fixed wiring periodic tests are required.

Date of Tests: 16 April 2017

Test Instrument: JPS0253A

Calibration Certificate Number: 17-020201

Calibration Due Date: 02 Feb 2018

Tested By: John Preston

Signed By:

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
<b>Client: D&amp;W Discos</b>		<b>Site: Flat 13 Watford</b>		<b>Location:</b>
Asset ID: A01633	Description: IEC LEAD 5A			Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.06	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
Overall: Pass				
Asset ID: A01634	Description: IEC LEAD 5A			Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.06	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
Overall: Pass				
Asset ID: A01636	Description: IEC LEAD 5A			Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.07	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
Overall: Pass				
Asset ID: A01641	Description: EXT LEAD			Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.15	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
Overall: Pass				
Asset ID: A01647	Description: EXT LEAD			Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.1	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
Overall: Pass				
Asset ID: A01650	Description: 1.5M IEC ADAPTOR FLEX			Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.11	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
Overall: Pass				
Asset ID: A01651	Description: IEC ADAPTOR FLEX 3M			Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.3	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
Overall: Pass				
Asset ID: A01652	Description: 4M IEC ADAPTOR FLEX			Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.24	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
Overall: Pass				
Asset ID: A01654	Description: IEC LEAD 5A			Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.06	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Polarity	16/04/2017			Pass
Overall: Pass				
<b>Asset ID: A01655</b>				
<b>Description: EXT REEL 12M</b>				
<b>Test Instrument: X39-0571</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.26	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
Overall: Pass				
<b>Asset ID: A01656</b>				
<b>Description: EXT REEL 25M</b>				
<b>Test Instrument: X39-0571</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.47	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
Overall: Pass				
<b>Asset ID: A01657</b>				
<b>Description: SOUNDLAB MUSHROOM LIGHT Model:SRL448 Serial:03060</b>				
<b>Test Instrument: X39-0571</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.09	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01659</b>				
<b>Description: FLOWER EFFECT LIGHT Model:150-283UK Serial:213000</b>				
<b>Test Instrument: X39-0571</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.06	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01662</b>				
<b>Description: CLASS2 LEAD</b>				
<b>Test Instrument: X39-0571</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01663</b>				
<b>Description: LAPTOP XFORMER</b>				
<b>Test Instrument: X39-0571</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01664</b>				
<b>Description: RADIOMIC</b>				
<b>Test Instrument: X39-0571</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Leakage	16/04/2017	<0.1	mA	Pass
Load	16/04/2017	<0.05	kVA	Information
Overall: Pass				
<b>Asset ID: A01665</b>				
<b>Description: 4 WAY CHASER LIGHT Model L70AK Serial:1680306073-</b>				
<b>Test Instrument: X39-0571</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.05	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01669</b>				
<b>Description: NJD DISCO LIGHT Model: DATAMOON Serial:452101213</b>				
<b>Test Instrument: X39-0571</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.09	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Overall: Pass				
<b>Asset ID: A01670</b>				
<b>Description: NJD DISCO LIGHT Model:DATAMOON Serial:452101271</b>				
<b>Test Instrument: X39-0571</b>				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.14	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	Overall: Pass
<b>Asset ID: A01671</b> Description: ACME EXERCET Model:MH-270M Serial:AE-02030678					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.12	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01672</b> Description: ACME EXERCET Model:MH-270M Serial:08020122					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.41	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01673</b> Description: SOUNDLABS WHITE LIGHT Model:DK008 Serial: 04040001					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.08	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01684</b> Description: IEC LEAD 5A					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.05	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A01685</b> Description: ACME DMX LIGHT Model:MH275R Serial:PL09050936					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.09	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01686</b> Description: IEC LEAD 5A					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.05	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A01687</b> Description: ACME DMX LIGHT Model:MH-275R Serial:PL09050915					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.1	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01688</b> Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.16	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01689</b> Description: ACME AUTOMATED LUMINAIRE SUPER LEO Serial:PL10041					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.13	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A01691</b> Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.13	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
				Overall: Pass

Asset ID:	Description:	Serial:	Test Instrument:	
A01692	ACME AUTOMATED LUMINAIRE SUPER SCIMITAR	09	X39-0571	
Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.09	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
				Overall: Pass

Asset ID:	Description:	Serial:	Test Instrument:	
A01693	ACME AUTOMATED LUMINAIRE SUPER SCIMITAR	09	X39-0571	
Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.08	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
				Overall: Pass

Asset ID:	Description:	Serial:	Test Instrument:	
A01702	MERRY CHRISTMAS LIGHT		X39-0571	
Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Leakage	16/04/2017	<0.1	mA	Pass
Load	16/04/2017	0.08	kVA	Information
				Overall: Pass

Asset ID:	Description:	Serial:	Test Instrument:	
A109085	IEC LEAD 5A		X39-0571	
Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.06	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
				Overall: Pass

Asset ID:	Description:	Serial:	Test Instrument:	
A109087	LAMP		X39-0571	
Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.18	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
				Overall: Pass

Asset ID:	Description:	Serial:	Test Instrument:	
A109088	LAMP		X39-0571	
Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.09	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
				Overall: Pass

Asset ID:	Description:	Serial:	Test Instrument:	
A109089	IEC LEAD 5A		X39-0571	
Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.04	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
				Overall: Pass

Asset ID:	Description:	Serial:	Test Instrument:	
A109090	IEC LEAD 5A		X39-0571	
Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.04	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
				Overall: Pass

Asset ID:	Description:	Serial:	Test Instrument:	
A109091	IEC LEAD 5A		X39-0571	
Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.04	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass
				Overall: Pass

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	Overall: Pass
<b>Asset ID: A140131</b>					<b>Description: SPEAKER</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.1	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A140132</b>					<b>Description: SPEAKER</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.1	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A140133</b>					<b>Description: IEC LEAD 5A</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.05	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A140134</b>					<b>Description: IEC ADAPTOR</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.09	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A140135</b>					<b>Description: LIGHTBAR</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.12	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A140136</b>					<b>Description: IEC LEAD 10A</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.05	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A140137</b>					<b>Description: IEC LEAD 10A</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.06	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A140138</b>					<b>Description: EXTENSION REEL</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.29	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A142246</b>					<b>Description: SOUNDLAB LIGHT</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.2	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					<b>Overall: Pass</b>

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
<b>Asset ID: A142247</b>					Test Instrument: X39-0571
<b>Description: SOUNDLAB LIGHT</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.06	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A142248</b>					Test Instrument: X39-0571
<b>Description: LAMP</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.1	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A142249</b>					Test Instrument: X39-0571
<b>Description: LAMP</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.11	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A142252</b>					Test Instrument: X39-0571
<b>Description: IEC ADAPTOR</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.24	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A142253</b>					Test Instrument: X39-0571
<b>Description: LIGHT CONTROLLER</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.08	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A142254</b>					Test Instrument: X39-0571
<b>Description: TRANSFORMER</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A142255</b>					Test Instrument: X39-0571
<b>Description: IEC ADAPTOR</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.11	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150519</b>					Test Instrument: X39-0571
<b>Description: LAMP</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.1	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A150520</b>					Test Instrument: X39-0571
<b>Description: SPEAKER</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.08	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A150521</b>					Test Instrument: X39-0571
<b>Description: SPEAKER</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.09	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	



# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	Overall: Pass
<b>Asset ID: A150522</b>					Test Instrument: X39-0571
<b>Description: SPEAKER</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.13	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A150523</b>					Test Instrument: X39-0571
<b>Description: SPEAKER</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.12	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A150524</b>					Test Instrument: X39-0571
<b>Description: SPEAKER</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.32	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A150525</b>					Test Instrument: X39-0571
<b>Description: SPEAKER</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.09	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A150526</b>					Test Instrument: X39-0571
<b>Description: MIXER 200FX</b>					
Comments: INSULATION ONLY TESTED					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhms	Pass	
					Overall: Pass
<b>Asset ID: A150527</b>					Test Instrument: X39-0571
<b>Description: IEC LEAD 3A</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.06	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150528</b>					Test Instrument: X39-0571
<b>Description: IEC LEAD 5A</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.05	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150529</b>					Test Instrument: X39-0571
<b>Description: EXTENSION LEAD</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.07	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150530</b>					Test Instrument: X39-0571
<b>Description: TRANSFORMER</b>					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A150531</b>					Test Instrument: X39-0571
<b>Description: NUMARK CDN88PRO</b>					
Comments: INSULATION ONLY TESTED					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhms	Pass	

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	Overall: Pass
<b>Asset ID: A150532</b> Description: LAMP					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Leakage	16/04/2017	<0.1	mA	Pass	
Load	16/04/2017	<0.05	kVA	Information	
					Overall: Pass
<b>Asset ID: A150533</b> Description: IEC LEAD 5A					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.18	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150534</b> Description: LAMP					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.09	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A150535</b> Description: LAMP					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.08	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A150536</b> Description: IEC LEAD 10A					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.06	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150537</b> Description: IEC LEAD 10A					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.05	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150538</b> Description: LAMP					Test Instrument: X39-0571
Comments: INSULATION ONLY TESTED					
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhms	Pass	
					Overall: Pass
<b>Asset ID: A150539</b> Description: LAMP					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhms	Pass	
					Overall: Pass
<b>Asset ID: A150540</b> Description: IEC LEAD 10A					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.06	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150541</b> Description: IEC LEAD 10A					Test Instrument: X39-0571
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Earth	16/04/2017	0.06	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass

Overall: Pass

Asset ID: A150542	Description: IEC LEAD 3A				Test Instrument: X39-0571
-------------------	--------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.05	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass

Overall: Pass

Asset ID: A150543	Description: IEC LEAD 3A				Test Instrument: X39-0571
-------------------	--------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.05	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass

Overall: Pass

Asset ID: A150544	Description: IEC LEAD 10A				Test Instrument: X39-0571
-------------------	---------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.09	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass

Overall: Pass

Asset ID: A150545	Description: IEC LEAD 10A				Test Instrument: X39-0571
-------------------	---------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.09	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass

Overall: Pass

Asset ID: A150546	Description: IEC LEAD 3A				Test Instrument: X39-0571
-------------------	--------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.05	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass

Overall: Pass

Asset ID: A150547	Description: IEC LEAD 3A				Test Instrument: X39-0571
-------------------	--------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.05	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass

Overall: Pass

Asset ID: A150548	Description: IEC ADAPTOR				Test Instrument: X39-0571
-------------------	--------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.13	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass

Overall: Pass

Asset ID: A150549	Description: IEC ADAPTOR				Test Instrument: X39-0571
-------------------	--------------------------	--	--	--	---------------------------

Test Type	Date	Result	Unit	Status
Visual	16/04/2017			Pass
Earth Current	16/04/2017	25	A	Information
Earth	16/04/2017	0.13	Ohm	Pass
Insulation	16/04/2017	>99.99	MOhm	Pass
Polarity	16/04/2017			Pass

Overall: Pass

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
<b>Asset ID: A150550</b>					<b>Description: IEC ADAPTOR</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.14	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150551</b>					<b>Description: IEC ADAPTOR</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.14	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150552</b>					<b>Description: IEC ADAPTOR</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.13	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150553</b>					<b>Description: IEC ADAPTOR</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.13	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150554</b>					<b>Description: IEC LEAD 10A</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.1	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150555</b>					<b>Description: IEC LEAD 10A</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.09	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150556</b>					<b>Description: IEC LEAD 10A</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.05	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150557</b>					<b>Description: EXTENSION LEAD</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.08	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					Overall: Pass
<b>Asset ID: A150558</b>					<b>Description: EXTENSION LEAD</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.08	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	Overall: Pass
<b>Asset ID: A21371</b>					<b>Description: EXT LEAD</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.14	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A21372</b>					<b>Description: EXT LEAD</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.12	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A21373</b>					<b>Description: HOMEBASE DESKLAMP Model GYT107 Serial:28112005</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A59476</b>					<b>Description: IEC LEAD 5A</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.06	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A59477</b>					<b>Description: URSA LASER</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.1	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A59478</b>					<b>Description: IEC LEAD 5A</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.18	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A59479</b>					<b>Description: MIXER NUMARK</b>
Comments: INSULATION ONLY TESTED					
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhms	Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A59480</b>					<b>Description: CD PLAYER</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A69503</b>					<b>Description: EXT LEAD</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.14	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Polarity	16/04/2017			Pass	
					<b>Overall: Pass</b>
<b>Asset ID: A69504</b>					<b>Description: CLASS2 LEAD</b>
<b>Test Type</b>					<b>Date</b>
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					<b>Overall: Pass</b>

# Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
<b>Asset ID: A69505</b>		<b>Description: AC ADAPTOR</b>			<b>Test Instrument: X39-0571</b>
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A81302</b>		<b>Description: CLASS1 LEAD</b>			<b>Test Instrument: X39-0571</b>
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Earth Current	16/04/2017	25	A	Information	
Earth	16/04/2017	0.07	Ohm	Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
					Overall: Pass
<b>Asset ID: A81303</b>		<b>Description: AC ADAPTOR</b>			<b>Test Instrument: X39-0571</b>
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>	
Visual	16/04/2017			Pass	
Insulation	16/04/2017	>99.99	MOhm	Pass	
Leakage	16/04/2017	<0.1	mA	Pass	
Load	16/04/2017	<0.05	kVA	Information	
					Overall: Pass

Total Tests: 107