



**REGISTER
OF
PORTABLE APPLIANCE TESTS**

On Behalf Of:

D &W Disco
Watford

Site Tested

D &W Disco
Watford

Date of Tests 08 April 2018



Test Certificate



Tests Conducted By: JPS Calibration Services Ltd, Commerce House, Telford Road, Bicester, Oxfordshire, OX26 4LD

On Behalf Of: D&W Discos, Watford, Herts,

Site:

Location:

Number of Tests: Number PASSED: Number FAILED

Number of Pages in Report:

Comments:

0 Fuses downrated to appropriate rating for flex csa.

The tests performed only indicate the status of the safety of the Unit Under Test and, although a functional test is performed, should not be misinterpreted as a verification of the units compliance with operational specifications. It must also be understood that some appliances (Class1) rely upon the fixed wiring of the socket to ensure continuity of the Earth connection. These Portable Appliance tests ensure the appliance under test has the correct Earth connection resistance but cannot ensure the continuity within the Fixed wiring of the supply and that Further Fixed wiring periodic tests are required.

Date of Tests:

Test Instrument:

Calibration Certificate Number:

Calibration Due Date:

Tested By:

Signed By:

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Client: D&W Discos		Site: Flat 13 Watford		Location:
Asset ID: A01633		Description: IEC LEAD 5A		Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.06	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A01634		Description: IEC LEAD 5A		Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.06	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A01636		Description: IEC LEAD 5A		Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.06	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A01641		Description: EXT LEAD		Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.14	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A01647		Description: EXT LEAD		Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.1	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A01650		Description: 1.5M IEC ADAPTOR FLEX		Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.11	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A01652		Description: 4M IEC ADAPTOR FLEX		Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.22	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A01654		Description: IEC LEAD 5A		Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.06	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A01655		Description: EXT REEL 12M		Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.26	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A01656 Description: EXT REEL 25M Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.46	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A01662 Description: CLASS2 LEAD Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01663 Description: LAPTOP XFORMER Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01664 Description: RADIOMIC Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01671 Description: ACME EXERCET Model:MH-270M Serial:AE-02030678 Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.12	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01672 Description: ACME EXERCET Model:MH-270M Serial:08020122 Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.07	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01673 Description: SOUNDLABS WHITE LIGHT Model:DK008 Serial: 04040001 Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.07	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01684 Description: IEC LEAD 5A Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.05	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A01690 Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:090 Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.09	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A01691 Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09 Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.11	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A01692					Test Instrument: X39-0571
Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.08	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A01693					Test Instrument: X39-0571
Description: ACME AUTOMATED LUMINAIRE SUPER SCIMITAR Serial:09					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.08	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A109084					Test Instrument: X39-0571
Description: IEC ADAPTOR					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.09	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
Overall: Pass					
Asset ID: A109085					Test Instrument: X39-0571
Description: IEC LEAD 5A					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.06	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
Overall: Pass					
Asset ID: A109087					Test Instrument: X39-0571
Description: LAMP					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.09	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A109088					Test Instrument: X39-0571
Description: LAMP					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.08	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A109089					Test Instrument: X39-0571
Description: IEC LEAD 5A					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.04	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
Overall: Pass					
Asset ID: A109090					Test Instrument: X39-0571
Description: IEC LEAD 5A					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.04	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
Overall: Pass					
Asset ID: A109091					Test Instrument: X39-0571
Description: IEC LEAD 5A					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.04	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
Overall: Pass					

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A140137					Description: IEC LEAD 10A
Test Type					Test Instrument: X39-0571
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.07	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass
Asset ID: A140138					Description: EXTENSION REEL
Test Type					Test Instrument: X39-0571
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.29	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass
Asset ID: A142254					Description: TRANSFORMER
Test Type					Test Instrument: X39-0571
Visual	08/04/2018			Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A142255					Description: IEC ADAPTOR
Test Type					Test Instrument: X39-0571
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.1	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass
Asset ID: A150520					Description: SPEAKER
Test Type					Test Instrument: X39-0571
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.1	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A150521					Description: SPEAKER
Test Type					Test Instrument: X39-0571
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.09	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A150523					Description: SPEAKER
Test Type					Test Instrument: X39-0571
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	<0.04	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A150524					Description: SPEAKER
Test Type					Test Instrument: X39-0571
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.08	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A150525					Description: SPEAKER
Test Type					Test Instrument: X39-0571
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.1	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A150526					Description: MIXER 200FX
Test Type					Test Instrument: X39-0571
Visual	08/04/2018			Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A150527					Description: IEC LEAD 3A
Test Type					Date
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.08	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A150528					Description: IEC LEAD 5A
Test Type					Date
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.07	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass
Asset ID: A150529					Description: EXTENSION LEAD
Test Type					Date
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.07	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass
Asset ID: A150530					Description: TRANSFORMER
Test Type					Date
Visual	08/04/2018			Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A150531					Description: NUMARK CDN88PRO
Test Type					Date
Visual	08/04/2018			Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A150532					Description: LAMP
Test Type					Date
Visual	08/04/2018			Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A150534					Description: LAMP
Test Type					Date
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.07	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A150535					Description: LAMP
Test Type					Date
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.08	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass
Asset ID: A150537					Description: IEC LEAD 10A
Test Type					Date
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.06	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass
Asset ID: A150541					Description: IEC LEAD 10A
Test Type					Date
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.06	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A150542					Description: IEC LEAD 3A
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.05	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Asset ID: A150543					Description: IEC LEAD 3A
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.05	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Asset ID: A150544					Description: IEC LEAD 10A
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.1	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Asset ID: A150545					Description: IEC LEAD 10A
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.1	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Asset ID: A150546					Description: IEC LEAD 3A
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.06	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Asset ID: A150547					Description: IEC LEAD 3A
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.05	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Asset ID: A150548					Description: IEC ADAPTOR
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.13	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Asset ID: A150549					Description: IEC ADAPTOR
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.13	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Asset ID: A150550					Description: IEC ADAPTOR
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.13	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	Overall: Pass
Asset ID: A150551					Description: IEC ADAPTOR
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.13	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Test Instrument: X39-0571					
Asset ID: A150552					Description: IEC ADAPTOR
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.13	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Test Instrument: X39-0571					
Asset ID: A150553					Description: IEC ADAPTOR
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.13	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Test Instrument: X39-0571					
Asset ID: A150554					Description: IEC LEAD 10A
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.1	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Test Instrument: X39-0571					
Asset ID: A150556					Description: IEC LEAD 10A
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.05	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Test Instrument: X39-0571					
Asset ID: A150557					Description: EXTENSION LEAD
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.08	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Test Instrument: X39-0571					
Asset ID: A154300					Description: IEC
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.22	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Test Instrument: X39-0571					
Asset ID: A154301					Description: EXT LEAD
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.08	Ohm		Pass
Insulation	08/04/2018	>99.99	MOhm		Pass
Polarity	08/04/2018				Pass
					Overall: Pass
Test Instrument: X39-0571					
Asset ID: A154302					Description: EXT LEAD
Test Type					Date
Visual	08/04/2018				Pass
Earth Current	08/04/2018	25	A		Information
Earth	08/04/2018	0.13	Ohm		Pass

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
				Overall: Pass

Asset ID: A154303	Description: EXT LEAD				Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.1	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass

Asset ID: A154304	Description: EXT LEAD				Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.08	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass

Asset ID: A154305	Description: EXT LEAD				Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.13	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass

Asset ID: A154306	Description: LAMP				Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.05	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass

Asset ID: A154307	Description: IEC				Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.07	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass

Asset ID: A154308	Description: LAMP				Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.1	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
					Overall: Pass

Asset ID: A154309	Description: IEC				Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.04	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass

Asset ID: A154310	Description: IEC				Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.04	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
					Overall: Pass

Asset ID: A154311	Description: LAMP				Test Instrument: X39-0571
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.07	Ohm	Pass	

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A154312				
Description: LAMP				
Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.07	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A154313				
Description: LAMP				
Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.06	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A154314				
Description: IEC				
Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	<0.04	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A154315				
Description: LAMP				
Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.04	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A154316				
Description: LAMP				
Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.08	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A154317				
Description: IEC				
Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.04	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A154318				
Description: IEC				
Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.04	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A154319				
Description: LAMP				
Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.07	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A154320				
Description: LAMP				
Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.08	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				

Detailed Latest Test Results



Test_Type	Test_Date	Result	Unit	Status	
Asset ID: A154321					Test Instrument: X39-0571
Description: SMOKE MC					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.06	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A154322					Test Instrument: X39-0571
Description: TRANSFORMER					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A154323					Test Instrument: X39-0571
Description: TRANSFORMER					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A154324					Test Instrument: X39-0571
Description: TRANSFORMER					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A154325					Test Instrument: X39-0571
Description: TRANSFORMER					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A154326					Test Instrument: X39-0571
Description: IEC					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.05	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
Overall: Pass					
Asset ID: A154327					Test Instrument: X39-0571
Description: SMOK MC					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.06	Ohm	Pass	
Insulation	08/04/2018	68.48	MOhm	Pass	
Overall: Pass					
Asset ID: A154328					Test Instrument: X39-0571
Description: IEC					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.04	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
Overall: Pass					
Asset ID: A21371					Test Instrument: X39-0571
Description: EXT LEAD					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.14	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Polarity	08/04/2018			Pass	
Overall: Pass					
Asset ID: A21373					Test Instrument: X39-0571
Description: HOMEBASE DESKLAMP Model GYT107 Serial:28112005					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: A59478					Test Instrument: X39-0571
Description: IEC LEAD 5A					
Test Type	Date	Result	Unit	Status	
Visual	08/04/2018			Pass	
Earth Current	08/04/2018	25	A	Information	
Earth	08/04/2018	0.07	Ohm	Pass	
Insulation	08/04/2018	>99.99	MOhm	Pass	



Test_Type	Test_Date	Result	Unit	Status
Overall: Pass				
Asset ID: A59479 Description: MIXER NUMARK Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A59480 Description: CD PLAYER Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A59482 Description: IEC LEAD 5A Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.06	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A69503 Description: EXT LEAD Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.15	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Polarity	08/04/2018			Pass
Overall: Pass				
Asset ID: A81302 Description: CLASS1 LEAD Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Earth Current	08/04/2018	25	A	Information
Earth	08/04/2018	0.06	Ohm	Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: A81303 Description: AC ADAPTOR Test Instrument: X39-0571				
Test Type	Date	Result	Unit	Status
Visual	08/04/2018			Pass
Insulation	08/04/2018	>99.99	MOhm	Pass
Overall: Pass				

Total Tests: 101